

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										NA			
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-9/19/07	030731711-0001	Southwest Area (sidewalk bridge level)	9/19/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST2-9/19/07	030731711-0002	Southeast Area (sidewalk bridge level)	9/19/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST4-9/19/07	030731711-0003	Northwest Area (street-level)	9/19/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST5-9/19/07	030731711-0004	Firehouse #10 (roof level)	9/19/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST10-9/19/07	030731711-0005	North Side Sidewalk Bridge	9/19/07	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST11-9/19/07	030731711-0006	90 Trinity Place (roof level)	9/19/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST12-9/19/07	030731711-0007	110 Greenwich Street (roof level)	9/19/07	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST13-9/19/07	030731711-0008	Marriott Hotel, 38th Floor (roof level)	9/19/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST14-9/19/07	030731711-0009	West Face - South end at corner (scaffolding level)	9/19/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST15-9/19/07	030731711-0010	South Face - East end at corner (scaffolding level)	9/19/07	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST16-9/19/07	030731711-0011	East Face - North end at corner (scaffolding level)	9/19/07	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST17-9/19/07	030731711-0012	North Face - West end at corner (scaffolding level)	9/19/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/20/07	< 13.00	No	No	
ASBESTOS-ST1-9/20/07	030731825-0001	Southwest Area (sidewalk bridge level)	9/20/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST2-9/20/07	030731825-0002	Southeast Area (sidewalk bridge level)	9/20/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST4-9/20/07	030731825-0003	Northwest Area (street-level)	9/20/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST5-9/20/07	030731825-0004	Firehouse #10 (roof level)	9/20/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST10-9/20/07	030731825-0005	North Side Sidewalk Bridge	9/20/07	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST100-9/20/07	030731825-0013	Station 10 Field Duplicate	9/20/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST11-9/20/07	030731825-0006	90 Trinity Place (roof level)	9/20/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST12-9/20/07	030731825-0007	110 Greenwich Street (roof level)	9/20/07	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST13-9/20/07	030731825-0008	Marriott Hotel, 38th Floor (roof level)	9/20/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST14-9/20/07	030731825-0009	West Face - South end at corner (scaffolding level)	9/20/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST15-9/20/07	030731825-0010	South Face - East end at corner (scaffolding level)	9/20/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST16-9/20/07	030731825-0011	East Face - North end at corner (scaffolding level)	9/20/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	
ASBESTOS-ST17-9/20/07	030731825-0012	North Face - West end at corner (scaffolding level)	9/20/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/07	< 13.00	No	No	