

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										Target Air Quality Levels			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-9/20/06	030630964-0001	Southwest Area (sidewalk bridge level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST2-9/20/06	030630964-0002	Southeast Area (sidewalk bridge level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST4-9/20/06	030630964-0003	Northwest Area (street-level)	9/20/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST5-9/20/06	030630964-0004	Firehouse #10 (roof level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST6-9/20/06	030630966-0001	Southwest Area (roof level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST7-9/20/06	030630966-0002	Southeast Area (roof level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST8-9/20/06	030630966-0003	Northeast Area (roof level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST9-9/20/06	030630966-0004	Northwest Area (roof level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST10-9/20/06	030630964-0005	North Side Sidewalk Bridge	9/20/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST11-9/20/06	030630964-0006	90 Trinity Place (roof level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST12-9/20/06	030630964-0007	110 Greenwich Street (roof level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST13-9/20/06	030630964-0008	Marriott Hotel, 38th Floor (roof level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST14-9/20/06	030630964-0009	West Face - South end at corner (scaffolding level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST15-9/20/06	030630964-0010	South Face - East end at corner (scaffolding level)	9/20/06	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST16-9/20/06	030630964-0011	East Face - North end at corner (scaffolding level)	9/20/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST17-9/20/06	030630964-0012	North Face - West end at corner (scaffolding level)	9/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/21/06	< 13.00	No	No	
ASBESTOS-ST1-9/21/06	030631091-0001	Southwest Area (sidewalk bridge level)	9/21/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST2-9/21/06	030631091-0002	Southeast Area (sidewalk bridge level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST4-9/21/06	030631091-0003	Northwest Area (street-level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST5-9/21/06	030631091-0004	Firehouse #10 (roof level)	9/21/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST6-9/21/06	030631092-0001	Southwest Area (roof level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST7-9/21/06	030631092-0002	Southeast Area (roof level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST8-9/21/06	030631092-0003	Northeast Area (roof level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST9-9/21/06	030631092-0004	Northwest Area (roof level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST10-9/21/06	030631091-0005	North Side Sidewalk Bridge	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST11-9/21/06	030631091-0006	90 Trinity Place (roof level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST12-9/21/06	030631091-0007	110 Greenwich Street (roof level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST13-9/21/06	030631091-0008	Marriott Hotel, 38th Floor (roof level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST14-9/21/06	030631091-0009	West Face - South end at corner (scaffolding level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST15-9/21/06	030631091-0010	South Face - East end at corner (scaffolding level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST16-9/21/06	030631091-0011	East Face - North end at corner (scaffolding level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	
ASBESTOS-ST17-9/21/06	030631091-0012	North Face - West end at corner (scaffolding level)	9/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	9/22/06	< 13.00	No	No	