

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-10/2/06	030632324-0001	Southwest Area (sidewalk bridge level)	10/2/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST2-10/2/06	030632324-0002	Southeast Area (sidewalk bridge level)	10/2/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST4-10/2/06	030632324-0003	Northwest Area (street-level)	10/2/06	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST5-10/2/06	030632324-0004	Firehouse #10 (roof level)	10/2/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST10-10/2/06	030632324-0005	North Side Sidewalk Bridge	10/2/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST11-10/2/06	030632324-0006	90 Trinity Place (roof level)	10/2/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST12-10/2/06	030632324-0007	110 Greenwich Street (roof level)	10/2/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST13-10/2/06	030632324-0008	Marriott Hotel, 38th Floor (roof level)	10/2/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST14-10/2/06	030632324-0009	West Face - South end at corner (scaffolding level)	10/2/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST15-10/2/06	030632324-0010	South Face - East end at corner (scaffolding level)	10/2/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST16-10/2/06	030632324-0011	East Face - North end at corner (scaffolding level)	10/2/06	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST17-10/2/06	030632324-0012	North Face - West end at corner (scaffolding level)	10/2/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/3/06	< 13.00	No	No	
ASBESTOS-ST1-10/3/06	030632461-0001	Southwest Area (sidewalk bridge level)	10/3/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST2-10/3/06	030632461-0002	Southeast Area (sidewalk bridge level)	10/3/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST4-10/3/06	030632461-0003	Northwest Area (street-level)	10/3/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST5-10/3/06	030632461-0004	Firehouse #10 (roof level)	10/3/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST10-10/3/06	030632461-0005	North Side Sidewalk Bridge	10/3/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST11-10/3/06	030632461-0006	90 Trinity Place (roof level)	10/3/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST12-10/3/06	030632461-0007	110 Greenwich Street (roof level)	10/3/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST13-10/3/06	030632461-0008	Marriott Hotel, 38th Floor (roof level)	10/3/06	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST14-10/3/06	030632461-0009	West Face - South end at corner (scaffolding level)	10/3/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST15-10/3/06	030632461-0010	South Face - East end at corner (scaffolding level)	10/3/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST16-10/3/06	030632461-0011	East Face - North end at corner (scaffolding level)	10/3/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	
ASBESTOS-ST17-10/3/06	030632461-0012	North Face - West end at corner (scaffolding level)	10/3/06	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/4/06	< 13.00	No	No	