

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-10/5/08	030835290-0001	Southwest Area (sidewalk bridge level)	10/5/08	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 15.00	No	No	
ASBESTOS-ST2-10/5/08	030835290-0002	Southeast Area (sidewalk bridge level)	10/5/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 13.00	No	No	
ASBESTOS-ST4-10/5/08	030835290-0003	Northwest Area (street-level)	10/5/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 15.00	No	No	
ASBESTOS-ST5-10/5/08	030835290-0004	Firehouse #10 (roof level)	10/5/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 13.00	No	No	
ASBESTOS-ST10-10/5/08	030835290-0005	North Side Sidewalk Bridge	10/5/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 15.00	No	No	
ASBESTOS-ST11-10/5/08	030835290-0006	90 Trinity Place (roof level)	10/5/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 13.00	No	No	
ASBESTOS-ST12-10/5/08	030835290-0007	110 Greenwich Street (roof level)	10/5/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 13.00	No	No	
ASBESTOS-ST13-10/5/08	030835290-0008	Marriott Hotel, 38th Floor (roof level)	10/5/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 15.00	No	No	
ASBESTOS-ST14-10/5/08	030835290-0009	West Face - South end at corner (scaffolding level)	10/5/08	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 15.00	No	No	
ASBESTOS-ST15-10/5/08	030835290-0010	South Face - East end at corner (scaffolding level)	10/5/08	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 15.00	No	No	
ASBESTOS-ST16-10/5/08	030835290-0011	East Face - North end at corner (scaffolding level)	10/5/08	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 15.00	No	No	
ASBESTOS-ST17-10/5/08	030835290-0012	North Face - West end at corner (scaffolding level)	10/5/08	1	3.220	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/6/08	< 15.00	No	No	
ASBESTOS-ST1-10/6/08	030835441-0001	Southwest Area (sidewalk bridge level)	10/6/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST2-10/6/08	030835441-0002	Southeast Area (sidewalk bridge level)	10/6/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST4-10/6/08	030835441-0003	Northwest Area (street-level)	10/6/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST5-10/6/08	030835441-0004	Firehouse #10 (roof level)	10/6/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST10-10/6/08	030835441-0005	North Side Sidewalk Bridge	10/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST11-10/6/08	030835441-0006	90 Trinity Place (roof level)	10/6/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST12-10/6/08	030835441-0007	110 Greenwich Street (roof level)	10/6/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST13-10/6/08	030835441-0008	Marriott Hotel, 38th Floor (roof level)	10/6/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST14-10/6/08	030835441-0009	West Face - South end at corner (scaffolding level)	10/6/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST15-10/6/08	030835441-0010	South Face - East end at corner (scaffolding level)	10/6/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST16-10/6/08	030835441-0011	East Face - North end at corner (scaffolding level)	10/6/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST17-10/6/08	030835441-0012	North Face - West end at corner (scaffolding level)	10/6/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/7/08	< 13.00	No	No	
ASBESTOS-ST1-10/7/08	030835607-0001	Southwest Area (sidewalk bridge level)	10/7/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 15.00	No	No	
ASBESTOS-ST2-10/7/08	030835607-0002	Southeast Area (sidewalk bridge level)	10/7/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 13.00	No	No	
ASBESTOS-ST4-10/7/08	030835607-0003	Northwest Area (street-level)	10/7/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 13.00	No	No	
ASBESTOS-ST5-10/7/08	030835607-0004	Firehouse #10 (roof level)	10/7/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 13.00	No	No	
ASBESTOS-ST10-10/7/08	030835607-0005	North Side Sidewalk Bridge	10/7/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 13.00	No	No	
ASBESTOS-ST11-10/7/08	030835607-0006	90 Trinity Place (roof level)	10/7/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 13.00	No	No	
ASBESTOS-ST12-10/7/08	030835607-0007	110 Greenwich Street (roof level)	10/7/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 13.00	No	No	
ASBESTOS-ST13-10/7/08	030835607-0008	Marriott Hotel, 38th Floor (roof level)	10/7/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 13.00	No	No	
ASBESTOS-ST14-10/7/08	030835607-0009	West Face - South end at corner (scaffolding level)	10/7/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 15.00	No	No	
ASBESTOS-ST15-10/7/08	030835607-0010	South Face - East end at corner (scaffolding level)	10/7/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 13.00	No	No	
ASBESTOS-ST16-10/7/08	030835607-0011	East Face - North end at corner (scaffolding level)	10/7/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 13.00	No	No	
ASBESTOS-ST17-10/7/08	030835607-0012	North Face - West end at corner (scaffolding level)	10/7/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/8/08	< 13.00	No	No	