

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA			
										70			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-10/9/06	030633184-0001	Southwest Area (sidewalk bridge level)	10/9/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST2-10/9/06	030633184-0002	Southeast Area (sidewalk bridge level)	10/9/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST4-10/9/06	030633184-0003	Northwest Area (street-level)	10/9/06	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST5-10/9/06	030633184-0004	Firehouse #10 (roof level)	10/9/06	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST10-10/9/06	030633184-0005	North Side Sidewalk Bridge	10/9/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST11-10/9/06	030633184-0006	90 Trinity Place (roof level)	10/9/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST12-10/9/06	030633184-0007	110 Greenwich Street (roof level)	10/9/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST13-10/9/06	030633184-0008	Marriott Hotel, 38th Floor (roof level)	10/9/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST14-10/9/06	030633184-0009	West Face - South end at corner (scaffolding level)	10/9/06	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST15-10/9/06	030633184-0010	South Face - East end at corner (scaffolding level)	10/9/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST16-10/9/06	030633184-0011	East Face - North end at corner (scaffolding level)	10/9/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST17-10/9/06	030633184-0012	North Face - West end at corner (scaffolding level)	10/9/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/10/06	< 13.00	No	No	
ASBESTOS-ST1-10/10/06	030633341-0001	Southwest Area (sidewalk bridge level)	10/10/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST2-10/10/06	030633341-0002	Southeast Area (sidewalk bridge level)	10/10/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST4-10/10/06	030633341-0003	Northwest Area (street-level)	10/10/06	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST5-10/10/06	030633341-0004	Firehouse #10 (roof level)	10/10/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST10-10/10/06	030633341-0005	North Side Sidewalk Bridge	10/10/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST11-10/10/06	030633341-0006	90 Trinity Place (roof level)	10/10/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST12-10/10/06	030633341-0007	110 Greenwich Street (roof level)	10/10/06	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST13-10/10/06	030633341-0008	Marriott Hotel, 38th Floor (roof level)	10/10/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST14-10/10/06	030633341-0009	West Face - South end at corner (scaffolding level)	10/10/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST15-10/10/06	030633341-0010	South Face - East end at corner (scaffolding level)	10/10/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST16-10/10/06	030633341-0011	East Face - North end at corner (scaffolding level)	10/10/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	
ASBESTOS-ST17-10/10/06	030633341-0012	North Face - West end at corner (scaffolding level)	10/10/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/11/06	< 13.00	No	No	