

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels											70			
ASBESTOS-ST1-10/14/08	030836561-0001	Southwest Area (sidewalk bridge level)	10/14/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 15.00	No	No		
ASBESTOS-ST2-10/14/08	030836561-0002	Southeast Area (sidewalk bridge level)	10/14/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 15.00	No	No		
ASBESTOS-ST4-10/14/08	030836561-0003	Northwest Area (street-level)	10/14/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 13.00	No	No		
ASBESTOS-ST5-10/14/08	030836561-0004	Firehouse #10 (roof level)	10/14/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 15.00	No	No		
ASBESTOS-ST10-10/14/08	030836561-0005	North Side Sidewalk Bridge	10/14/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 13.00	No	No		
ASBESTOS-ST11-10/14/08	030836561-0006	90 Trinity Place (roof level)	10/14/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 13.00	No	No		
ASBESTOS-ST12-10/14/08	030836561-0007	110 Greenwich Street (roof level)	10/14/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 13.00	No	No		
ASBESTOS-ST13-10/14/08	030836561-0008	Marriott Hotel, 38th Floor (roof level)	10/14/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 13.00	No	No		
ASBESTOS-ST14-10/14/08	030836561-0009	West Face - South end at corner (scaffolding level)	10/14/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 15.00	No	No		
ASBESTOS-ST15-10/14/08	030836561-0010	South Face - East end at corner (scaffolding level)	10/14/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 13.00	No	No		
ASBESTOS-ST16-10/14/08	030836561-0011	East Face - North end at corner (scaffolding level)	10/14/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 13.00	No	No		
ASBESTOS-ST17-10/14/08	030836561-0012	North Face - West end at corner (scaffolding level)	10/14/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/15/08	< 13.00	No	No		
ASBESTOS-ST1-10/15/08	030836703-0001	Southwest Area (sidewalk bridge level)	10/15/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST2-10/15/08	030836703-0002	Southeast Area (sidewalk bridge level)	10/15/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST4-10/15/08	030836703-0003	Northwest Area (street-level)	10/15/08	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST5-10/15/08	030836703-0004	Firehouse #10 (roof level)	10/15/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST10-10/15/08	030836703-0005	North Side Sidewalk Bridge	10/15/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST11-10/15/08	030836703-0006	90 Trinity Place (roof level)	10/15/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST12-10/15/08	030836703-0007	110 Greenwich Street (roof level)	10/15/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST13-10/15/08	030836703-0008	Marriott Hotel, 38th Floor (roof level)	10/15/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST14-10/15/08	030836703-0009	West Face - South end at corner (scaffolding level)	10/15/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST15-10/15/08	030836703-0010	South Face - East end at corner (scaffolding level)	10/15/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST16-10/15/08	030836703-0011	East Face - North end at corner (scaffolding level)	10/15/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		
ASBESTOS-ST17-10/15/08	030836703-0012	North Face - West end at corner (scaffolding level)	10/15/08	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/16/08	< 13.00	No	No		