

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-10/16/08	030836880-0001	Southwest Area (sidewalk bridge level)	10/16/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST2-10/16/08	030836880-0002	Southeast Area (sidewalk bridge level)	10/16/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST4-10/16/08	030836880-0003	Northwest Area (street-level)	10/16/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST5-10/16/08	030836880-0004	Firehouse #10 (roof level)	10/16/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST10-10/16/08	030836880-0005	North Side Sidewalk Bridge	10/16/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST11-10/16/08	030836880-0006	90 Trinity Place (roof level)	10/16/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST12-10/16/08	030836880-0007	110 Greenwich Street (roof level)	10/16/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST13-10/16/08	030836880-0008	Marriott Hotel, 38th Floor (roof level)	10/16/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST14-10/16/08	030836880-0009	West Face - South end at corner (scaffolding level)	10/16/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST15-10/16/08	030836880-0010	South Face - East end at corner (scaffolding level)	10/16/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST16-10/16/08	030836880-0011	East Face - North end at corner (scaffolding level)	10/16/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST17-10/16/08	030836880-0012	North Face - West end at corner (scaffolding level)	10/16/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/17/08	< 13.00	No	No	
ASBESTOS-ST1-10/17/08	030836965-0001	Southwest Area (sidewalk bridge level)	10/17/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST2-10/17/08	030836965-0002	Southeast Area (sidewalk bridge level)	10/17/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST4-10/17/08	030836965-0003	Northwest Area (street-level)	10/17/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST5-10/17/08	030836965-0004	Firehouse #10 (roof level)	10/17/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST10-10/17/08	030836965-0005	North Side Sidewalk Bridge	10/17/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST100-10/17/08	030836965-0013	Station 10 Field Duplicate	10/17/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST11-10/17/08	030836965-0006	90 Trinity Place (roof level)	10/17/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST12-10/17/08	030836965-0007	110 Greenwich Street (roof level)	10/17/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST13-10/17/08	030836965-0008	Marriott Hotel, 38th Floor (roof level)	10/17/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST14-10/17/08	030836965-0009	West Face - South end at corner (scaffolding level)	10/17/08	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST15-10/17/08	030836965-0010	South Face - East end at corner (scaffolding level)	10/17/08	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST16-10/17/08	030836965-0011	East Face - North end at corner (scaffolding level)	10/17/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	
ASBESTOS-ST17-10/17/08	030836965-0012	North Face - West end at corner (scaffolding level)	10/17/08	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/18/08	< 13.00	No	No	