

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality	Site Specific	Comments
EPA Site Specific Trigger Levels										70	Levels	Trigger Levels	
ASBESTOS-ST1-10/27/08	030838293-0001	Southwest Area (sidewalk bridge level)	10/27/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 13.00	No	No	
ASBESTOS-ST2-10/27/08	030838293-0002	Southeast Area (sidewalk bridge level)	10/27/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 13.00	No	No	
ASBESTOS-ST4-10/27/08	030838293-0003	Northwest Area (street-level)	10/27/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 13.00	No	No	
ASBESTOS-ST5-10/27/08	030838293-0004	Firehouse #10 (roof level)	10/27/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 13.00	No	No	
ASBESTOS-ST10-10/27/08	030838293-0005	North Side Sidewalk Bridge	10/27/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 13.00	No	No	
ASBESTOS-ST100-10/27/08	030838293-0013	Station 10 Field Duplicate	10/27/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 15.00	No	No	
ASBESTOS-ST11-10/27/08	030838293-0006	90 Trinity Place (roof level)	10/27/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 13.00	No	No	
ASBESTOS-ST12-10/27/08	030838293-0007	110 Greenwich Street (roof level)	10/27/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 13.00	No	No	
ASBESTOS-ST13-10/27/08	030838293-0008	Marriott Hotel, 38th Floor (roof level)	10/27/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 13.00	No	No	
ASBESTOS-ST14-10/27/08	030838293-0009	West Face - South end at corner (scaffolding level)	10/27/08	1	3.250	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 15.00	No	No	
ASBESTOS-ST15-10/27/08	030838293-0010	South Face - East end at corner (scaffolding level)	10/27/08	1	3.310	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 15.00	No	No	
ASBESTOS-ST16-10/27/08	030838293-0011	East Face - North end at corner (scaffolding level)	10/27/08	1	3.410	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 15.00	No	No	
ASBESTOS-ST17-10/27/08	030838293-0012	North Face - West end at corner (scaffolding level)	10/27/08	1	3.270	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/28/08	< 15.00	No	No	
ASBESTOS-ST1-10/28/08	030838454-0001	Southwest Area (sidewalk bridge level)	10/28/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST2-10/28/08	030838454-0002	Southeast Area (sidewalk bridge level)	10/28/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST4-10/28/08	030838454-0003	Northwest Area (street-level)	10/28/08	1	2.880	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST5-10/28/08	030838454-0004	Firehouse #10 (roof level)	10/28/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST10-10/28/08	030838454-0005	North Side Sidewalk Bridge	10/28/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST11-10/28/08	030838454-0006	90 Trinity Place (roof level)	10/28/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST12-10/28/08	030838454-0007	110 Greenwich Street (roof level)	10/28/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST13-10/28/08	030838454-0008	Marriott Hotel, 38th Floor (roof level)	10/28/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST14-10/28/08	030838454-0009	West Face - South end at corner (scaffolding level)	10/28/08	1	2.870	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST15-10/28/08	030838454-0010	South Face - East end at corner (scaffolding level)	10/28/08	1	2.680	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST16-10/28/08	030838454-0011	East Face - North end at corner (scaffolding level)	10/28/08	1	2.700	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	
ASBESTOS-ST17-10/28/08	030838454-0012	North Face - West end at corner (scaffolding level)	10/28/08	1	2.690	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	10/29/08	< 13.00	No	No	