

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels											NA		
EPA Site Specific Trigger Levels											70		
ASBESTOS-ST1-11/1/06	030635802-0001	Southwest Area (sidewalk bridge level)	11/1/06	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST2-11/1/06	030635802-0002	Southeast Area (sidewalk bridge level)	11/1/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST4-11/1/06	030635802-0003	Northwest Area (street-level)	11/1/06	1	3.130	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST5-11/1/06	030635802-0004	Firehouse #10 (roof level)	11/1/06	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST10-11/1/06	030635802-0005	North Side Sidewalk Bridge	11/1/06	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST11-11/1/06	030635802-0006	90 Trinity Place (roof level)	11/1/06	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST12-11/01/06	030635802-0007	110 Greenwich Street (roof level)	11/1/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST13-11/1/06	030635802-0008	Marriott Hotel, 38th Floor (roof level)	11/1/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST14-11/1/06	030635802-0009	West Face - South end at corner (scaffolding level)	11/1/06	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST15-11/1/06	030635802-0010	South Face - East end at corner (scaffolding level)	11/1/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST16-11/1/06	030635802-0011	East Face - North end at corner (scaffolding level)	11/1/06	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST17-11/1/06	030635802-0012	North Face - West end at corner (scaffolding level)	11/1/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/2/06	< 13.00	No	No	
ASBESTOS-ST1-11/02/06	030635938-0001	Southwest Area (sidewalk bridge level)	11/2/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST2-11/02/06	030635938-0002	Southeast Area (sidewalk bridge level)	11/2/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST4-11/02/06	030635938-0003	Northwest Area (street-level)	11/2/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST5-11/02/06	030635938-0004	Firehouse #10 (roof level)	11/2/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST10-11/02/06	030635938-0005	North Side Sidewalk Bridge	11/2/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST11-11/02/06	030635938-0006	90 Trinity Place (roof level)	11/2/06	1	2.840	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST12-11/02/06	030635938-0007	110 Greenwich Street (roof level)	11/2/06	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST13-11/02/06	030635938-0008	Marriott Hotel, 38th Floor (roof level)	11/2/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST14-11/02/06	030635938-0009	West Face - South end at corner (scaffolding level)	11/2/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST15-11/02/06	030635938-0010	South Face - East end at corner (scaffolding level)	11/2/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST16-11/02/06	030635938-0011	East Face - North end at corner (scaffolding level)	11/2/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	
ASBESTOS-ST17-11/02/06	030635938-0012	North Face - West end at corner (scaffolding level)	11/2/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/3/06	< 13.00	No	No	