

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										NA			
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-11/7/08	030839793-0001	Southwest Area (sidewalk bridge level)	11/7/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST2-11/7/08	030839793-0002	Southeast Area (sidewalk bridge level)	11/7/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST4-11/7/08	030839793-0003	Northwest Area (street-level)	11/7/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST5-11/7/08	030839793-0004	Firehouse #10 (roof level)	11/7/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST10-11/7/08	030839793-0005	North Side Sidewalk Bridge	11/7/08	1	2.830	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST11-11/7/08	030839793-0006	90 Trinity Place (roof level)	11/7/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST12-11/7/08	030839793-0007	110 Greenwich Street (roof level)	11/7/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST13-11/7/08	030839793-0008	Marriott Hotel, 38th Floor (roof level)	11/7/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST14-11/7/08	030839793-0009	West Face - South end at corner (scaffolding level)	11/7/08	1	2.780	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST15-11/7/08	030839793-0010	South Face - East end at corner (scaffolding level)	11/7/08	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST16-11/7/08	030839793-0011	East Face - North end at corner (scaffolding level)	11/7/08	1	2.750	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	
ASBESTOS-ST17-11/7/08	030839793-0012	North Face - West end at corner (scaffolding level)	11/7/08	1	2.760	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/8/08	< 13.00	No	No	