TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m^3)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										NA			
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-11/18/05	030535058-0001	Southwest Area (street-level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST2-11/18/05	030535058-0002	Southeast Area (sidewalk bridge level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST4-11/18/05	030535058-0003	Northwest Area (street-level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST5-11/18/05	030535058-0004	Firehouse #10 (roof level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST10-11/18/05	030535058-0005	North Side Sidewalk Bridge	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST11-11/18/05	030535058-0006	90 Trinity Place (roof level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST12-11/18/05	030535058-0007	110 Greenwich Street (roof level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST13-11/18/05	030535058-0008	Marriott Hotel, 38th Floor (roof level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST14-11/18/05	030535058-0009	West Face - South end at corner (scaffolding level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST15-11/18/05	030535058-0010	South Face - East end at corner (scaffolding level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST16-11/18/05	030535058-0011	East Face - North end at corner (scaffolding level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST17-11/18/05	030535058-0012	North Face - West end at corner (scaffolding level)	11/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST1-11/19/05	030535059-0001	Southwest Area (street-level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST2-11/19/05	030535059-0002	Southeast Area (sidewalk bridge level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST4-11/19/05	030535059-0003	Northwest Area (street-level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST5-11/19/05	030535059-0004	Firehouse #10 (roof level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST10-11/19/05	030535059-0005	North Side Sidewalk Bridge	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST11-11/19/05	030535059-0006	90 Trinity Place (roof level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST12-11/19/05	030535059-0007	110 Greenwich Street (roof level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST13-11/19/05	030535059-0008	Marriott Hotel, 38th Floor (roof level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST14-11/19/05	030535059-0009	West Face - South end at corner (scaffolding level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST15-11/19/05	030535059-0010	South Face - East end at corner (scaffolding level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST16-11/19/05	030535059-0011	East Face - North end at corner (scaffolding level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST17-11/19/05	030535059-0012	North Face - West end at corner (scaffolding level)	11/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST1-11/20/05	030535060-0001	Southwest Area (street-level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST2-11/20/05	030535060-0002	Southeast Area (sidewalk bridge level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST4-11/20/05	030535060-0003	Northwest Area (street-level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST5-11/20/05	030535060-0004	Firehouse #10 (roof level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST10-11/20/05	030535060-0005	North Side Sidewalk Bridge	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST11-11/20/05	030535060-0006	90 Trinity Place (roof level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST12-11/20/05	030535060-0007	110 Greenwich Street (roof level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST13-11/20/05	030535060-0008	Marriott Hotel, 38th Floor (roof level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST14-11/20/05	030535060-0009	West Face - South end at corner (scaffolding level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST15-11/20/05	030535060-0010	South Face - East end at corner (scaffolding level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST16-11/20/05	030535060-0011	East Face - North end at corner (scaffolding level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST17-11/20/05	030535060-0012	North Face - West end at corner (scaffolding level)	11/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/05	< 13.00	No	No	
ASBESTOS-ST1-11/21/05	030535169-0001	Southwest Area (street-level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST2-11/21/05	030535169-0002	Southeast Area (sidewalk bridge level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST4-11/21/05	030535169-0003	Northwest Area (street-level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST5-11/21/05	030535169-0004	Firehouse #10 (roof level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST10-11/21/05	030535169-0005	North Side Sidewalk Bridge	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST11-11/21/05	030535169-0006	90 Trinity Place (roof level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST12-11/21/05	030535169-0007	110 Greenwich Street (roof level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST13-11/21/05	030535169-0008	Marriott Hotel, 38th Floor (roof level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST14-11/21/05	030535169-0009	West Face - South end at corner (scaffolding level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST15-11/21/05	030535169-0010	South Face - East end at corner (scaffolding level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST16-11/21/05	030535169-0011	East Face - North end at corner (scaffolding level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	
ASBESTOS-ST17-11/21/05	030535169-0012	North Face - West end at corner (scaffolding level)	11/21/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/22/05	< 13.00	No	No	