

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-11/20/08	030841399-0001	Southwest Area (sidewalk bridge level)	11/20/08	1	2.370	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 11.00	No	No	Note 1
ASBESTOS-ST2-11/20/08	030841399-0002	Southeast Area (sidewalk bridge level)	11/20/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST4-11/20/08	030841399-0003	Northwest Area (street-level)	11/20/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST5-11/20/08	030841399-0004	Firehouse #10 (roof level)	11/20/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST10-11/20/08	030841399-0005	North Side Sidewalk Bridge	11/20/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST100-11/20/08	030841399-0012	Station 10 Field Duplicate	11/20/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST11-11/20/08	030841399-0006	90 Trinity Place (roof level)	11/20/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST12-11/20/08	030841399-0007	110 Greenwich Street (roof level)	11/20/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	13.00	No	No	
ASBESTOS-ST13-11/20/08	030841399-0008	Marriott Hotel, 38th Floor (roof level)	11/20/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST14-11/20/08	030841399-0009	West Face - South end at corner (scaffolding level)	11/20/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST15-11/20/08	030841399-0010	South Face - East end at corner (scaffolding level)	11/20/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST16-11/20/08	030841399-0011	East Face - North end at corner (scaffolding level)	11/20/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST17-11/20/08	030841399-0012	North Face - West end at corner (scaffolding level)	11/20/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/21/08	< 13.00	No	No	
ASBESTOS-ST1-11/21/08	030841534-0001	Southwest Area (sidewalk bridge level)	11/21/08	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST2-11/21/08	030841534-0002	Southeast Area (sidewalk bridge level)	11/21/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST4-11/21/08	030841534-0003	Northwest Area (street-level)	11/21/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST5-11/21/08	030841534-0004	Firehouse #10 (roof level)	11/21/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST10-11/21/08	030841534-0005	North Side Sidewalk Bridge	11/21/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST11-11/21/08	030841534-0006	90 Trinity Place (roof level)	11/21/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST12-11/21/08	030841534-0007	110 Greenwich Street (roof level)	11/21/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST13-11/21/08	030841534-0008	Marriott Hotel, 38th Floor (roof level)	11/21/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST14-11/21/08	030841534-0009	West Face - South end at corner (scaffolding level)	11/21/08	1	2.810	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST15-11/21/08	030841534-0010	South Face - East end at corner (scaffolding level)	11/21/08	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST16-11/21/08	030841534-0011	East Face - North end at corner (scaffolding level)	11/21/08	1	2.910	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST17-11/21/08	030841534-0012	North Face - West end at corner (scaffolding level)	11/21/08	1	2.860	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST1-11/22/08	030841641-0001	Southwest Area (sidewalk bridge level)	11/22/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST2-11/22/08	030841641-0002	Southeast Area (sidewalk bridge level)	11/22/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST4-11/22/08	030841641-0003	Northwest Area (street-level)	11/22/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST5-11/22/08	030841641-0004	Firehouse #10 (roof level)	11/22/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST10-11/22/08	030841641-0005	North Side Sidewalk Bridge	11/22/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 15.00	No	No	
ASBESTOS-ST11-11/22/08	030841641-0006	90 Trinity Place (roof level)	11/22/08	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST12-11/22/08	030841641-0007	110 Greenwich Street (roof level)	11/22/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 15.00	No	No	
ASBESTOS-ST13-11/22/08	030841641-0008	Marriott Hotel, 38th Floor (roof level)	11/22/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST14-11/22/08	030841641-0009	West Face - South end at corner (scaffolding level)	11/22/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST15-11/22/08	030841641-0010	South Face - East end at corner (scaffolding level)	11/22/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST16-11/22/08	030841641-0011	East Face - North end at corner (scaffolding level)	11/22/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST17-11/22/08	030841641-0012	North Face - West end at corner (scaffolding level)	11/22/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST1-11/23/08	030841645-0001	Southwest Area (sidewalk bridge level)	11/23/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 15.00	No	No	
ASBESTOS-ST2-11/23/08	030841645-0002	Southeast Area (sidewalk bridge level)	11/23/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST4-11/23/08	030841645-0003	Northwest Area (street-level)	11/23/08	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 15.00	No	No	
ASBESTOS-ST5-11/23/08	030841645-0004	Firehouse #10 (roof level)	11/23/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST10-11/23/08	030841645-0005	North Side Sidewalk Bridge	11/23/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 15.00	No	No	
ASBESTOS-ST11-11/23/08	030841645-0006	90 Trinity Place (roof level)	11/23/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST12-11/23/08	030841645-0007	110 Greenwich Street (roof level)	11/23/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST13-11/23/08	030841645-0008	Marriott Hotel, 38th Floor (roof level)	11/23/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 13.00	No	No	
ASBESTOS-ST14-11/23/08	030841645-0009	West Face - South end at corner (scaffolding level)	11/23/08	1	3.290	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 15.00	No	No	
ASBESTOS-ST15-11/23/08	030841645-0010	South Face - East end at corner (scaffolding level)	11/23/08	1	3.330	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 15.00	No	No	
ASBESTOS-ST16-11/23/08	030841645-0011	East Face - North end at corner (scaffolding level)	11/23/08	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 15.00	No	No	
ASBESTOS-ST17-11/23/08	030841645-0012	North Face - West end at corner (scaffolding level)	11/23/08	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/24/08	< 15.00	No	No	

Note:

1. The asbestos sample from Station 1 (Southwest Area [sidewalk bridge level]) on November 20, 2008 was of a decreased volume on account of intermittent power outages.