

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels											70			
ASBESTOS-ST1-11/22/05	030535320-0001	Southwest Area (street-level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST2-11/22/05	030535320-0002	Southeast Area (sidewalk bridge level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST4-11/22/05	030535320-0003	Northwest Area (street-level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST5-11/22/05	030535320-0004	Firehouse #10 (roof level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST10-11/22/05	030535320-0005	North Side Sidewalk Bridge	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST11-11/22/05	030535320-0006	90 Trinity Place (roof level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST12-11/22/05	030535320-0007	110 Greenwich Street (roof level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST13-11/22/05	030535320-0008	Marriott Hotel, 38th Floor (roof level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST14-11/22/05	030535320-0009	West Face - South end at corner (scaffolding level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST15-11/22/05	030535320-0010	South Face - East end at corner (scaffolding level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST16-11/22/05	030535320-0011	East Face - North end at corner (scaffolding level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST17-11/22/05	030535320-0012	North Face - West end at corner (scaffolding level)	11/22/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/23/05	< 13.00	No	No		
ASBESTOS-ST1-11/24/05	030535403-0001	Southwest Area (street-level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST2-11/24/05	030535403-0002	Southeast Area (sidewalk bridge level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST4-11/24/05	030535403-0003	Northwest Area (street-level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST5-11/24/05	030535403-0004	Firehouse #10 (roof level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST10-11/24/05	030535403-0005	North Side Sidewalk Bridge	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST11-11/24/05	030535403-0006	90 Trinity Place (roof level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST12-11/24/05	030535403-0007	110 Greenwich Street (roof level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST13-11/24/05	030535403-0008	Marriott Hotel, 38th Floor (roof level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST14-11/24/05	030535403-0009	West Face - South end at corner (scaffolding level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST15-11/24/05	030535403-0010	South Face - East end at corner (scaffolding level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST16-11/24/05	030535403-0011	East Face - North end at corner (scaffolding level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST17-11/24/05	030535403-0012	North Face - West end at corner (scaffolding level)	11/24/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST1-11/25/05	030535456-0001	Southwest Area (street-level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST2-11/25/05	030535456-0002	Southeast Area (sidewalk bridge level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST4-11/25/05	030535456-0003	Northwest Area (street-level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST5-11/25/05	030535456-0004	Firehouse #10 (roof level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST10-11/25/05	030535456-0005	North Side Sidewalk Bridge	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST11-11/25/05	030535456-0006	90 Trinity Place (roof level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	32.00	No	No		
ASBESTOS-ST12-11/25/05	030535456-0007	110 Greenwich Street (roof level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST13-11/25/05	030535456-0008	Marriott Hotel, 38th Floor (roof level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST14-11/25/05	030535456-0009	West Face - South end at corner (scaffolding level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST15-11/25/05	030535456-0010	South Face - East end at corner (scaffolding level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST16-11/25/05	030535456-0011	East Face - North end at corner (scaffolding level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		
ASBESTOS-ST17-11/25/05	030535456-0012	North Face - West end at corner (scaffolding level)	11/25/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/26/05	< 13.00	No	No		