

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										NA			
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-11/27/06	030638436-0001	Southwest Area (sidewalk bridge level)	11/27/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST2-11/27/06	030638436-0002	Southeast Area (sidewalk bridge level)	11/27/06	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST4-11/27/06	030638436-0003	Northwest Area (street-level)	11/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST5-11/27/06	030638436-0004	Firehouse #10 (roof level)	11/27/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST10-11/27/06	030638436-0005	North Side Sidewalk Bridge	11/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST100-11/27/06	030638436-0013	Station 10 Field Duplicate	11/27/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST11-11/27/06	030638436-0006	90 Trinity Place (roof level)	11/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST12-11/27/06	030638436-0007	110 Greenwich Street (roof level)	11/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST13-11/27/06	030638436-0008	Marriott Hotel, 38th Floor (roof level)	11/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST14-11/27/06	030638436-0009	West Face - South end at corner (scaffolding level)	11/27/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST15-11/27/06	030638436-0010	South Face - East end at corner (scaffolding level)	11/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST16-11/27/06	030638436-0011	East Face - North end at corner (scaffolding level)	11/27/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST17-11/27/06	030638436-0012	North Face - West end at corner (scaffolding level)	11/27/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/28/06	< 13.00	No	No	
ASBESTOS-ST1-11/28/06	030638585-0001	Southwest Area (sidewalk bridge level)	11/28/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST2-11/28/06	030638585-0002	Southeast Area (sidewalk bridge level)	11/28/06	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST4-11/28/06	030638585-0003	Northwest Area (street-level)	11/28/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST5-11/28/06	030638585-0004	Firehouse #10 (roof level)	11/28/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST10-11/28/06	030638585-0005	North Side Sidewalk Bridge	11/28/06	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST11-11/28/06	030638585-0006	90 Trinity Place (roof level)	11/28/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST12-11/28/06	030638585-0007	110 Greenwich Street (roof level)	11/28/06	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST13-11/28/06	030638585-0008	Marriott Hotel, 38th Floor (roof level)	11/28/06	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST14-11/28/06	030638585-0009	West Face - South end at corner (scaffolding level)	11/28/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST15-11/28/06	030638585-0010	South Face - East end at corner (scaffolding level)	11/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST16-11/28/06	030638585-0011	East Face - North end at corner (scaffolding level)	11/28/06	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	
ASBESTOS-ST17-11/28/06	030638585-0012	North Face - West end at corner (scaffolding level)	11/28/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	11/29/06	< 13.00	No	No	