

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels											Air Quality Levels	Site Specific Trigger Levels	Comments
EPA Site Specific Trigger Levels											NA	70	
ASBESTOS-ST1-12/8/06	030639889-0001	Southwest Area (sidewalk bridge level)	12/8/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST2-12/8/06	030639889-0002	Southeast Area (sidewalk bridge level)	12/8/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST4-12/8/06	030639889-0003	Northwest Area (street-level)	12/8/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST5-12/8/06	030639889-0004	Firehouse #10 (roof level)	12/8/06	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST10-12/8/06	030639889-0005	North Side Sidewalk Bridge	12/8/06	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 13.00	No	No	
ASBESTOS-ST11-12/8/06	030639889-0006	90 Trinity Place (roof level)	12/8/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST12-12/8/06	030639889-0007	110 Greenwich Street (roof level)	12/8/06	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST13-12/8/06	030639889-0008	Marriott Hotel, 38th Floor (roof level)	12/8/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST14-12/8/06	030639889-0009	West Face - South end at corner (scaffolding level)	12/8/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST15-12/8/06	030639889-0010	South Face - East end at corner (scaffolding level)	12/8/06	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST16-12/8/06	030639889-0011	East Face - North end at corner (scaffolding level)	12/8/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST17-12/8/06	030639889-0012	North Face - West end at corner (scaffolding level)	12/8/06	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 13.00	No	No	
ASBESTOS-ST1-12/9/06	030639890-0001	Southwest Area (sidewalk bridge level)	12/9/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST2-12/9/06	030639890-0002	Southeast Area (sidewalk bridge level)	12/9/06	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST4-12/9/06	030639890-0003	Northwest Area (street-level)	12/9/06	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST5-12/9/06	030639890-0004	Firehouse #10 (roof level)	12/9/06	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 13.00	No	No	
ASBESTOS-ST10-12/9/06	030639890-0005	North Side Sidewalk Bridge	12/9/06	1	3.230	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST11-12/9/06	030639890-0006	90 Trinity Place (roof level)	12/9/06	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST12-12/9/06	030639890-0007	110 Greenwich Street (roof level)	12/9/06	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST13-12/9/06	030639890-0008	Marriott Hotel, 38th Floor (roof level)	12/9/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST14-12/9/06	030639890-0009	West Face - South end at corner (scaffolding level)	12/9/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST15-12/9/06	030639890-0010	South Face - East end at corner (scaffolding level)	12/9/06	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST16-12/9/06	030639890-0011	East Face - North end at corner (scaffolding level)	12/9/06	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST17-12/9/06	030639890-0012	North Face - West end at corner (scaffolding level)	12/9/06	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 13.00	No	No	
ASBESTOS-ST1-12/10/06	030639891-0001	Southwest Area (sidewalk bridge level)	12/10/06	1	3.150	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST2-12/10/06	030639891-0002	Southeast Area (sidewalk bridge level)	12/10/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST4-12/10/06	030639891-0003	Northwest Area (street-level)	12/10/06	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST5-12/10/06	030639891-0004	Firehouse #10 (roof level)	12/10/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST10-12/10/06	030639891-0005	North Side Sidewalk Bridge	12/10/06	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST11-12/10/06	030639891-0006	90 Trinity Place (roof level)	12/10/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 13.00	No	No	
ASBESTOS-ST12-12/10/06	030639891-0007	110 Greenwich Street (roof level)	12/10/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST13-12/10/06	030639891-0008	Marriott Hotel, 38th Floor (roof level)	12/10/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST14-12/10/06	030639891-0009	West Face - South end at corner (scaffolding level)	12/10/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST15-12/10/06	030639891-0010	South Face - East end at corner (scaffolding level)	12/10/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST16-12/10/06	030639891-0011	East Face - North end at corner (scaffolding level)	12/10/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST17-12/10/06	030639891-0012	North Face - West end at corner (scaffolding level)	12/10/06	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/06	< 15.00	No	No	
ASBESTOS-ST1-12/11/06	030640031-0001	Southwest Area (sidewalk bridge level)	12/11/06	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	
ASBESTOS-ST2-12/11/06	030640031-0002	Southeast Area (sidewalk bridge level)	12/11/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	
ASBESTOS-ST4-12/11/06	030640031-0003	Northwest Area (street-level)	12/11/06	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	
ASBESTOS-ST5-12/11/06	030640031-0004	Firehouse #10 (roof level)	12/11/06	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	
ASBESTOS-ST10-12/11/06	030640031-0005	North Side Sidewalk Bridge	12/11/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	
ASBESTOS-ST11-12/11/06	030640031-0006	90 Trinity Place (roof level)	12/11/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 13.00	No	No	
ASBESTOS-ST12-12/11/06	030640031-0007	110 Greenwich Street (roof level)	12/11/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	
ASBESTOS-ST13-12/11/06	030640031-0008	Marriott Hotel, 38th Floor (roof level)	12/11/06	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	
ASBESTOS-ST14-12/11/06	030640031-0009	West Face - South end at corner (scaffolding level)	12/11/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	
ASBESTOS-ST15-12/11/06	030640031-0010	South Face - East end at corner (scaffolding level)	12/11/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	
ASBESTOS-ST16-12/11/06	030640031-0011	East Face - North end at corner (scaffolding level)	12/11/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	
ASBESTOS-ST17-12/11/06	030640031-0012	North Face - West end at corner (scaffolding level)	12/11/06	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/06	< 15.00	No	No	