

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA	70			
										Target Air Quality Levels				
										EPA Site Specific Trigger Levels				
ASBESTOS-ST1-12/9/08	030843277-0001	Southwest Area (sidewalk bridge level)	12/9/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST2-12/9/08	030843277-0002	Southeast Area (sidewalk bridge level)	12/9/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST4-12/9/08	030843277-0003	Northwest Area (street-level)	12/9/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST5-12/9/08	030843277-0004	Firehouse #10 (roof level)	12/9/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST10-12/9/08	030843277-0005	North Side Sidewalk Bridge	12/9/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST100-12/9/08	030843277-0013	Station 10 Field Duplicate	12/9/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST11-12/9/08	030843277-0006	90 Trinity Place (roof level)	12/9/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST12-12/9/08	030843277-0007	110 Greenwich Street (roof level)	12/9/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST13-12/9/08	030843277-0008	Marriott Hotel, 38th Floor (roof level)	12/9/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST14-12/9/08	030843277-0009	West Face - South end at corner (scaffolding level)	12/9/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST15-12/9/08	030843277-0010	South Face - East end at corner (scaffolding level)	12/9/08	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST16-12/9/08	030843277-0011	East Face - North end at corner (scaffolding level)	12/9/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST17-12/9/08	030843277-0012	North Face - West end at corner (scaffolding level)	12/9/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/10/08	< 13.00		No	No	
ASBESTOS-ST1-12/10/08	030843398-0001	Southwest Area (sidewalk bridge level)	12/10/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST2-12/10/08	030843398-0002	Southeast Area (sidewalk bridge level)	12/10/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST4-12/10/08	030843398-0003	Northwest Area (street-level)	12/10/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST5-12/10/08	030843398-0004	Firehouse #10 (roof level)	12/10/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST10-12/10/08	030843398-0005	North Side Sidewalk Bridge	12/10/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST11-12/10/08	030843398-0006	90 Trinity Place (roof level)	12/10/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST12-12/10/08	030843398-0007	110 Greenwich Street (roof level)	12/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST13-12/10/08	030843398-0008	Marriott Hotel, 38th Floor (roof level)	12/10/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST14-12/10/08	030843398-0009	West Face - South end at corner (scaffolding level)	12/10/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST15-12/10/08	030843398-0010	South Face - East end at corner (scaffolding level)	12/10/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST16-12/10/08	030843398-0011	East Face - North end at corner (scaffolding level)	12/10/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST17-12/10/08	030843398-0012	North Face - West end at corner (scaffolding level)	12/10/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/11/08	< 13.00		No	No	
ASBESTOS-ST1-12/11/08	030843513-0001	Southwest Area (sidewalk bridge level)	12/11/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST2-12/11/08	030843513-0002	Southeast Area (sidewalk bridge level)	12/11/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST4-12/11/08	030843513-0003	Northwest Area (street-level)	12/11/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST5-12/11/08	030843513-0004	Firehouse #10 (roof level)	12/11/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST10-12/11/08	030843513-0005	North Side Sidewalk Bridge	12/11/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST11-12/11/08	030843513-0006	90 Trinity Place (roof level)	12/11/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST12-12/11/08	030843513-0007	110 Greenwich Street (roof level)	12/11/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST13-12/11/08	030843513-0008	Marriott Hotel, 38th Floor (roof level)	12/11/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST14-12/11/08	030843513-0009	West Face - South end at corner (scaffolding level)	12/11/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST15-12/11/08	030843513-0010	South Face - East end at corner (scaffolding level)	12/11/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST16-12/11/08	030843513-0011	East Face - North end at corner (scaffolding level)	12/11/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	
ASBESTOS-ST17-12/11/08	030843513-0012	North Face - West end at corner (scaffolding level)	12/11/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/12/08	< 13.00		No	No	