

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality	Site Specific	
										70	Levels	Trigger Levels	
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-12/13/07	030738896-0001	Southwest Area (sidewalk bridge level)	12/13/07	1	2.730	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/14/07	< 13.00	No	No	
ASBESTOS-ST2-12/13/07	030738896-0002	Southeast Area (sidewalk bridge level)	12/13/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/14/07	< 13.00	No	No	
ASBESTOS-ST4-12/13/07	030738896-0003	Northwest Area (street-level)	12/13/07	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/14/07	< 13.00	No	No	
ASBESTOS-ST5-12/13/07	030738896-0004	Firehouse #10 (roof level)	12/13/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/14/07	< 13.00	No	No	
ASBESTOS-ST10-12/13/07	030738896-0005	North Side Sidewalk Bridge	12/13/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/14/07	< 13.00	No	No	
ASBESTOS-ST11-12/13/07	030738896-0006	90 Trinity Place (roof level)	12/13/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/14/07	< 13.00	No	No	
ASBESTOS-ST12-12/13/07	030738896-0007	110 Greenwich Street (roof level)	12/13/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/14/07	< 13.00	No	No	
ASBESTOS-ST13-12/13/07	030738896-0008	Marriott Hotel, 38th Floor (roof level)	12/13/07	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/14/07	< 13.00	No	No	
ASBESTOS-ST14-12/13/07	030738981-0001	West Face - South end at corner (scaffolding level)	12/13/07	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST15-12/13/07	030738981-0002	South Face - East end at corner (scaffolding level)	12/13/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST16-12/13/07	030738981-0003	East Face - North end at corner (scaffolding level)	12/13/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST17-12/13/07	030738981-0004	North Face - West end at corner (scaffolding level)	12/13/07	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST1-12/14/07	030738987-0001	Southwest Area (sidewalk bridge level)	12/14/07	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST2-12/14/07	030738987-0002	Southeast Area (sidewalk bridge level)	12/14/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST4-12/14/07	030738987-0003	Northwest Area (street-level)	12/14/07	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST5-12/14/07	030738987-0004	Firehouse #10 (roof level)	12/14/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST10-12/14/07	030738987-0005	North Side Sidewalk Bridge	12/14/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST100-12/14/07	030738987-0013	Station 10 Field Duplicate	12/14/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST11-12/14/07	030738987-0006	90 Trinity Place (roof level)	12/14/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST12-12/14/07	030738987-0007	110 Greenwich Street (roof level)	12/14/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST13-12/14/07	030738987-0008	Marriott Hotel, 38th Floor (roof level)	12/14/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST14-12/14/07	030738987-0009	West Face - South end at corner (scaffolding level)	12/14/07	1	3.570	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST15-12/14/07	030738987-0010	South Face - East end at corner (scaffolding level)	12/14/07	1	3.500	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST16-12/14/07	030738987-0011	East Face - North end at corner (scaffolding level)	12/14/07	1	3.550	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	
ASBESTOS-ST17-12/14/07	030738987-0012	North Face - West end at corner (scaffolding level)	12/14/07	1	3.680	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/07	< 13.00	No	No	