

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality	Site Specific	
										70	Levels	Trigger Levels	
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-12/16/05	030537830-0001	Southwest Area (sidewalk bridge level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST2-12/16/05	030537830-0002	Southeast Area (sidewalk bridge level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST4-12/16/05	030537830-0003	Northwest Area (street-level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST5-12/16/05	030537830-0004	Firehouse #10 (roof level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST10-12/16/05	030537830-0005	North Side Sidewalk Bridge	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST11-12/16/05	030537830-0006	90 Trinity Place (roof level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST12-12/16/05	030537830-0007	110 Greenwich Street (roof level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST13-12/16/05	030537830-0008	Marriott Hotel, 38th Floor (roof level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST14-12/16/05	030537830-0009	West Face - South end at corner (scaffolding level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST15-12/16/05	030537830-0010	South Face - East end at corner (scaffolding level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST16-12/16/05	030537830-0011	East Face - North end at corner (scaffolding level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST17-12/16/05	030537830-0012	North Face - West end at corner (scaffolding level)	12/16/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST1-12/17/05	030537831-0001	Southwest Area (sidewalk bridge level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST2-12/17/05	030537831-0002	Southeast Area (sidewalk bridge level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST4-12/17/05	030537831-0003	Northwest Area (street-level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST5-12/17/05	030537831-0004	Firehouse #10 (roof level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST10-12/17/05	030537831-0005	North Side Sidewalk Bridge	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST11-12/17/05	030537831-0006	90 Trinity Place (roof level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST12-12/17/05	030537831-0007	110 Greenwich Street (roof level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST13-12/17/05	030537831-0008	Marriott Hotel, 38th Floor (roof level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST14-12/17/05	030537831-0009	West Face - South end at corner (scaffolding level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST15-12/17/05	030537831-0010	South Face - East end at corner (scaffolding level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST16-12/17/05	030537831-0011	East Face - North end at corner (scaffolding level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST17-12/17/05	030537831-0012	North Face - West end at corner (scaffolding level)	12/17/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/05	< 13.00	No	No	
ASBESTOS-ST1-12/18/05	030537832-0001	Southwest Area (sidewalk bridge level)	12/18/05	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST2-12/18/05	030537832-0002	Southeast Area (sidewalk bridge level)	12/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST4-12/18/05	030537832-0003	Northwest Area (street-level)	12/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST5-12/18/05	030537832-0004	Firehouse #10 (roof level)	12/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST10-12/18/05	030537832-0005	North Side Sidewalk Bridge	12/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST11-12/18/05	030537832-0006	90 Trinity Place (roof level)	12/18/05	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST12-12/18/05	030537832-0007	110 Greenwich Street (roof level)	12/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST13-12/18/05	030537832-0008	Marriott Hotel, 38th Floor (roof level)	12/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST14-12/18/05	030537832-0009	West Face - South end at corner (scaffolding level)	12/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST15-12/18/05	030537832-0010	South Face - East end at corner (scaffolding level)	12/18/05	1	2.750	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST16-12/18/05	030537832-0011	East Face - North end at corner (scaffolding level)	12/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	
ASBESTOS-ST17-12/18/05	030537832-0012	North Face - West end at corner (scaffolding level)	12/18/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No	