

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-12/17/08	030844094-0001	Southwest Area (sidewalk bridge level)	12/17/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST2-12/17/08	030844094-0002	Southeast Area (sidewalk bridge level)	12/17/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST4-12/17/08	030844094-0003	Northwest Area (street-level)	12/17/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST5-12/17/08	030844094-0004	Firehouse #10 (roof level)	12/17/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST10-12/17/08	030844094-0005	North Side Sidewalk Bridge	12/17/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST100-12/17/08	030844094-0013	Station 10 Field Duplicate	12/17/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST11-12/17/08	030844094-0006	90 Trinity Place (roof level)	12/17/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST12-12/17/08	030844094-0007	110 Greenwich Street (roof level)	12/17/08	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST13-12/17/08	030844094-0008	Marriott Hotel, 38th Floor (roof level)	12/17/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST14-12/17/08	030844094-0009	West Face - South end at corner (scaffolding level)	12/17/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST15-12/17/08	030844094-0010	South Face - East end at corner (scaffolding level)	12/17/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST16-12/17/08	030844094-0011	East Face - North end at corner (scaffolding level)	12/17/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST17-12/17/08	030844094-0012	North Face - West end at corner (scaffolding level)	12/17/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/18/08	< 13.00	No	No	
ASBESTOS-ST1-12/18/08	030844192-0001	Southwest Area (sidewalk bridge level)	12/18/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST2-12/18/08	030844192-0002	Southeast Area (sidewalk bridge level)	12/18/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST4-12/18/08	030844192-0003	Northwest Area (street-level)	12/18/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST5-12/18/08	030844192-0004	Firehouse #10 (roof level)	12/18/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST10-12/18/08	030844192-0005	North Side Sidewalk Bridge	12/18/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST11-12/18/08	030844192-0006	90 Trinity Place (roof level)	12/18/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST12-12/18/08	030844192-0007	110 Greenwich Street (roof level)	12/18/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST13-12/18/08	030844192-0008	Marriott Hotel, 38th Floor (roof level)	12/18/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST14-12/18/08	030844192-0009	West Face - South end at corner (scaffolding level)	12/18/08	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST15-12/18/08	030844192-0010	South Face - East end at corner (scaffolding level)	12/18/08	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST16-12/18/08	030844192-0011	East Face - North end at corner (scaffolding level)	12/18/08	1	2.870	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST17-12/18/08	030844192-0012	North Face - West end at corner (scaffolding level)	12/18/08	1	2.790	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/19/08	< 13.00	No	No	
ASBESTOS-ST1-12/19/08	030844254-0001	Southwest Area (sidewalk bridge level)	12/19/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST2-12/19/08	030844254-0002	Southeast Area (sidewalk bridge level)	12/19/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST4-12/19/08	030844254-0003	Northwest Area (street-level)	12/19/08	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST5-12/19/08	030844254-0004	Firehouse #10 (roof level)	12/19/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST10-12/19/08	030844254-0005	North Side Sidewalk Bridge	12/19/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST11-12/19/08	030844254-0006	90 Trinity Place (roof level)	12/19/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST12-12/19/08	030844254-0007	110 Greenwich Street (roof level)	12/19/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST13-12/19/08	030844254-0008	Marriott Hotel, 38th Floor (roof level)	12/19/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST14-12/19/08	030844254-0009	West Face - South end at corner (scaffolding level)	12/19/08	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST15-12/19/08	030844254-0010	South Face - East end at corner (scaffolding level)	12/19/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST16-12/19/08	030844254-0011	East Face - North end at corner (scaffolding level)	12/19/08	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	
ASBESTOS-ST17-12/19/08	030844254-0012	North Face - West end at corner (scaffolding level)	12/19/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/08	< 13.00	No	No	