

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels											70			
ASBESTOS-ST1-12/19/05	030537933-0001	Southwest Area (sidewalk bridge level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST2-12/19/05	030537933-0002	Southeast Area (sidewalk bridge level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST4-12/19/05	030537933-0003	Northwest Area (street-level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST5-12/19/05	030537933-0004	Firehouse #10 (roof level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST10-12/19/05	030537933-0005	North Side Sidewalk Bridge	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST11-12/19/05	030537933-0006	90 Trinity Place (roof level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST12-12/19/05	030537933-0007	110 Greenwich Street (roof level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST13-12/19/05	030537933-0008	Marriott Hotel, 38th Floor (roof level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST14-12/19/05	030537933-0009	West Face - South end at corner (scaffolding level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST15-12/19/05	030537933-0010	South Face - East end at corner (scaffolding level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST16-12/19/05	030537933-0011	East Face - North end at corner (scaffolding level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST17-12/19/05	030537933-0012	North Face - West end at corner (scaffolding level)	12/19/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/20/05	< 13.00	No	No		
ASBESTOS-ST1-12/20/05	030538087-0001	Southwest Area (sidewalk bridge level)	12/20/05	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 15.00	No	No		
ASBESTOS-ST2-12/20/05	030538087-0002	Southeast Area (sidewalk bridge level)	12/20/05	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		
ASBESTOS-ST4-12/20/05	030538087-0003	Northwest Area (street-level)	12/20/05	1	2.860	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		
ASBESTOS-ST5-12/20/05	030538087-0004	Firehouse #10 (roof level)	12/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		
ASBESTOS-ST10-12/20/05	030538087-0005	North Side Sidewalk Bridge	12/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		
ASBESTOS-ST11-12/20/05	030538087-0006	90 Trinity Place (roof level)	12/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		
ASBESTOS-ST12-12/20/05	030538087-0007	110 Greenwich Street (roof level)	12/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		
ASBESTOS-ST13-12/20/05	030538087-0008	Marriott Hotel, 38th Floor (roof level)	12/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		
ASBESTOS-ST14-12/20/05	030538087-0009	West Face - South end at corner (scaffolding level)	12/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		
ASBESTOS-ST15-12/20/05	030538087-0010	South Face - East end at corner (scaffolding level)	12/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		
ASBESTOS-ST16-12/20/05	030538087-0011	East Face - North end at corner (scaffolding level)	12/20/05	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		
ASBESTOS-ST17-12/20/05	030538087-0012	North Face - West end at corner (scaffolding level)	12/20/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/05	< 13.00	No	No		