

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-12/20/06	030641160-0001	Southwest Area (sidewalk bridge level)	12/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST2-12/20/06	030641160-0002	Southeast Area (sidewalk bridge level)	12/20/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST4-12/20/06	030641160-0003	Northwest Area (street-level)	12/20/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST5-12/20/06	030641160-0004	Firehouse #10 (roof level)	12/20/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST10-12/20/06	030641160-0005	North Side Sidewalk Bridge	12/20/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST100-12/20/06	030641160-0013	Station 10 Field Duplicate	12/20/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST11-12/20/06	030641160-0006	90 Trinity Place (roof level)	12/20/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST12-12/20/06	030641160-0007	110 Greenwich Street (roof level)	12/20/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST13-12/20/06	030641160-0008	Marriott Hotel, 38th Floor (roof level)	12/20/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST14-12/20/06	030641160-0009	West Face - South end at corner (scaffolding level)	12/20/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST15-12/20/06	030641160-0010	South Face - East end at corner (scaffolding level)	12/20/06	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST16-12/20/06	030641160-0011	East Face - North end at corner (scaffolding level)	12/20/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST17-12/20/06	030641160-0012	North Face - West end at corner (scaffolding level)	12/20/06	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/21/06	< 13.00	No	No	
ASBESTOS-ST1-12/21/06	030641273-0001	Southwest Area (sidewalk bridge level)	12/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST2-12/21/06	030641273-0002	Southeast Area (sidewalk bridge level)	12/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST4-12/21/06	030641273-0003	Northwest Area (street-level)	12/21/06	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST5-12/21/06	030641273-0004	Firehouse #10 (roof level)	12/21/06	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST10-12/21/06	030641273-0005	North Side Sidewalk Bridge	12/21/06	1	3.190	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST11-12/21/06	030641273-0006	90 Trinity Place (roof level)	12/21/06	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST12-12/21/06	030641273-0007	110 Greenwich Street (roof level)	12/21/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST13-12/21/06	030641273-0008	Marriott Hotel, 38th Floor (roof level)	12/21/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST14-12/21/06	030641273-0009	West Face - South end at corner (scaffolding level)	12/21/06	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST15-12/21/06	030641273-0010	South Face - East end at corner (scaffolding level)	12/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST16-12/21/06	030641273-0011	East Face - North end at corner (scaffolding level)	12/21/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	
ASBESTOS-ST17-12/21/06	030641273-0012	North Face - West end at corner (scaffolding level)	12/21/06	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/22/06	< 13.00	No	No	