

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)		Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										Target Air Quality Levels				
										NA	70			
EPA Site Specific Trigger Levels										NA	70			
ASBESTOS-ST1-12/29/07	030740167-0001	Southwest Area (sidewalk bridge level)	12/29/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST2-12/29/07	030740167-0002	Southeast Area (sidewalk bridge level)	12/29/07	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST4-12/29/07	030740167-0003	Northwest Area (street-level)	12/29/07	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST5-12/29/07	030740167-0004	Firehouse #10 (roof level)	12/29/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST10-12/29/07	030740167-0005	North Side Sidewalk Bridge	12/29/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST11-12/29/07	030740167-0006	90 Trinity Place (roof level)	12/29/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST12-12/29/07	030740167-0007	110 Greenwich Street (roof level)	12/29/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST13-12/29/07	030740167-0008	Marriott Hotel, 38th Floor (roof level)	12/29/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST14-12/29/07	030740167-0009	West Face - South end at corner (scaffolding level)	12/29/07	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST15-12/29/07	030740167-0010	South Face - East end at corner (scaffolding level)	12/29/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST16-12/29/07	030740167-0011	East Face - North end at corner (scaffolding level)	12/29/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST17-12/29/07	030740167-0012	North Face - West end at corner (scaffolding level)	12/29/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 15.00	< 13.00	No	No	
ASBESTOS-ST1-12/30/07	030740168-0001	Southwest Area (sidewalk bridge level)	12/30/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST2-12/30/07	030740168-0002	Southeast Area (sidewalk bridge level)	12/30/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST4-12/30/07	030740168-0003	Northwest Area (street-level)	12/30/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST5-12/30/07	030740168-0004	Firehouse #10 (roof level)	12/30/07	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST10-12/30/07	030740168-0005	North Side Sidewalk Bridge	12/30/07	1	2.950	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST11-12/30/07	030740168-0006	90 Trinity Place (roof level)	12/30/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST12-12/30/07	030740168-0007	110 Greenwich Street (roof level)	12/30/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST13-12/30/07	030740168-0008	Marriott Hotel, 38th Floor (roof level)	12/30/07	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST14-12/30/07	030740168-0009	West Face - South end at corner (scaffolding level)	12/30/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST15-12/30/07	030740168-0010	South Face - East end at corner (scaffolding level)	12/30/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST16-12/30/07	030740168-0011	East Face - North end at corner (scaffolding level)	12/30/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST17-12/30/07	030740168-0012	North Face - West end at corner (scaffolding level)	12/30/07	1	3.140	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/31/07	< 13.00	< 13.00	No	No	
ASBESTOS-ST1-12/31/07	030800039-0001	Southwest Area (sidewalk bridge level)	12/31/07	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST2-12/31/07	030800039-0002	Southeast Area (sidewalk bridge level)	12/31/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST4-12/31/07	030800039-0003	Northwest Area (street-level)	12/31/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST5-12/31/07	030800039-0004	Firehouse #10 (roof level)	12/31/07	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST10-12/31/07	030800039-0005	North Side Sidewalk Bridge	12/31/07	1	3.090	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST11-12/31/07	030800039-0006	90 Trinity Place (roof level)	12/31/07	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST12-12/31/07	030800039-0007	110 Greenwich Street (roof level)	12/31/07	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST13-12/31/07	030800039-0008	Marriott Hotel, 38th Floor (roof level)	12/31/07	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST14-12/31/07	030800039-0009	West Face - South end at corner (scaffolding level)	12/31/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST15-12/31/07	030800039-0010	South Face - East end at corner (scaffolding level)	12/31/07	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST16-12/31/07	030800039-0011	East Face - North end at corner (scaffolding level)	12/31/07	1	2.480	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 11.00	< 13.00	No	No	
ASBESTOS-ST17-12/31/07	030800039-0012	North Face - West end at corner (scaffolding level)	12/31/07	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST1-1/1/08	030800038-0001	Southwest Area (sidewalk bridge level)	1/1/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST2-1/1/08	030800038-0002	Southeast Area (sidewalk bridge level)	1/1/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST4-1/1/08	030800038-0003	Northwest Area (street-level)	1/1/08	1	3.180	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST5-1/1/08	030800038-0004	Firehouse #10 (roof level)	1/1/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST10-1/1/08	030800038-0005	North Side Sidewalk Bridge	1/1/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST11-1/1/08	030800038-0006	90 Trinity Place (roof level)	1/1/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST12-1/1/08	030800038-0007	110 Greenwich Street (roof level)	1/1/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST13-1/1/08	030800038-0008	Marriott Hotel, 38th Floor (roof level)	1/1/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST14-1/1/08	030800038-0009	West Face - South end at corner (scaffolding level)	1/1/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST15-1/1/08	030800038-0010	South Face - East end at corner (scaffolding level)	1/1/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	
ASBESTOS-ST16-1/1/08	030800038-0011	East Face - North end at corner (scaffolding level)	1/1/08	1	2.490	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 11.00	< 13.00	No	No	
ASBESTOS-ST17-1/1/08	030800038-0012	North Face - West end at corner (scaffolding level)	1/1/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	1/2/08	< 13.00	< 13.00	No	No	