

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Antimony Concentration (ng/m ³)	Barium Concentration (ng/m ³)	Beryllium Concentration (ng/m ³)	Cadmium Concentration (ng/m ³)	Chromium (Total) Concentration (ng/m ³)	Copper Concentration (ng/m ³)	Lead Concentration (ng/m ³)	Manganese Concentration (ng/m ³)	Nickel Concentration (ng/m ³)	Zinc Concentration (ng/m ³)	Exceeds Target	Exceeds EPA	Comments	
									5,000	5,000	20	40	600	10,000	1,500	500	200	16,000				
									14,000	5,000	200	400	600	100,000	5,000	500	28,000	160,000	Air Quality	Site Specific	Comments	
									Levels	Levels	Levels	Levels	Levels	Levels	Levels	Levels	Levels	Levels	Levels	Levels	Levels	Levels
METALS-ST1-5/23/07	G7E250219001	Southwest Area (sidewalk bridge level)	5/23/07	1762.2	Metals	6020	STL-SAC	5/25/07	1.9	< 68.1	< 0.68	< 0.68	< 6.8	235	20.5	26.9	6.1	84.5	No	No		
METALS-ST2-5/23/07	G7E250219002	Southeast Area (sidewalk bridge level)	5/23/07	1773.7	Metals	6020	STL-SAC	5/25/07	2.1	< 67.6	< 0.68	< 0.68	< 6.8	112	20.7	26.5	5.9	84.0	No	No		
METALS-ST4-5/23/07	G7E250219003	Northwest Area (street-level)	5/23/07	1781.2	Metals	6020	STL-SAC	5/25/07	2.1	< 67.4	< 0.67	< 0.67	< 6.7	65.2	38.4	31.8	6.5	134	No	No		
METALS-ST5-5/23/07	G7E250219004	Firehouse #10 (roof level)	5/23/07	1782.9	Metals	6020	STL-SAC	5/25/07	2.2	< 67.3	< 0.67	< 0.67	8.0	85.1	24.2	53.6	12.1	152	No	No		
METALS-ST10-5/23/07	G7E250219005	North Side Sidewalk Bridge	5/23/07	1787.1	Metals	6020	STL-SAC	5/25/07	2.2	< 67.1	< 0.67	< 0.67	8.3	195	27.6	46.3	9.0	171	No	No		
METALS-ST100-5/23/07	G7E250219013	Station 10 Field Duplicate	5/23/07	1800.9	Metals	6020	STL-SAC	5/25/07	2.2	< 66.6	< 0.67	< 0.67	8.2	103	33.8	50.0	9.6	162	No	No		
METALS-ST11-5/23/07	G7E250219006	90 Trinity Place (roof level)	5/23/07	1781.6	Metals	6020	STL-SAC	5/25/07	1.8	< 67.4	< 0.67	< 0.67	< 6.7	99.8	18.4	23.5	5.4	80.6	No	No		
METALS-ST12-5/23/07	G7E250219007	110 Greenwich Street (roof level)	5/23/07	1777.9	Metals	6020	STL-SAC	5/25/07	1.6	< 67.5	< 0.67	< 0.67	< 6.7	63.3	24.3	27.8	6.4	79.7	No	No		
METALS-ST13-5/23/07	G7E250219008	Marriot Hotel, 38th Floor (roof level)	5/23/07	1785.9	Metals	6020	STL-SAC	5/25/07	1.4	< 67.2	< 0.67	< 0.67	< 6.7	121	16.5	16.5	5.6	61.8	No	No		
METALS-ST14-5/23/07	G7E250219009	West Face - South end at corner (scaffolding level)	5/23/07	1787.9	Metals	6020	STL-SAC	5/25/07	< 1.3	< 67.1	< 0.67	< 0.67	< 6.7	117	16.8	19.1	5.5	59.7	No	No		
METALS-ST15-5/23/07	G7E250219010	South Face - East end at corner (scaffolding level)	5/23/07	1823.9	Metals	6020	STL-SAC	5/25/07	1.4	< 65.8	< 0.66	< 0.66	< 6.6	63.2	16.2	19.1	5.5	63.4	No	No		
METALS-ST16-5/23/07	G7E250219011	East Face - North end at corner (scaffolding level)	5/23/07	1810.8	Metals	6020	STL-SAC	5/25/07	1.6	< 66.3	< 0.66	< 0.66	< 6.6	107	16.2	25.1	5.9	89.6	No	No		
METALS-ST17-5/23/07	G7E250219012	North Face - West end at corner (scaffolding level)	5/23/07	1822.3	Metals	6020	STL-SAC	5/25/07	1.5	< 65.8	< 0.66	< 0.66	< 6.6	92.2	15.6	6.0	26.8	104	No	No		
METALS-ST1-5/24/07	G7E260194001	Southwest Area (sidewalk bridge level)	5/24/07	1733.3	Metals	6020	STL-SAC	5/26/07	3.7	< 69.2	< 0.69	< 0.69	< 6.9	125	21.3	36.1	8.4	106	No	No		
METALS-ST2-5/24/07	G7E260194002	Southeast Area (sidewalk bridge level)	5/24/07	1757.8	Metals	6020	STL-SAC	5/26/07	3.3	< 68.3	< 0.68	< 0.68	< 6.8	66.8	17.6	34.0	8.7	76.7	No	No		
METALS-ST4-5/24/07	G7E260194003	Northwest Area (street-level)	5/24/07	1754.6	Metals	6020	STL-SAC	5/26/07	3.5	< 68.4	< 0.68	< 0.68	7.9	73.8	32.8	35.5	8.1	119	No	No		
METALS-ST5-5/24/07	G7E260194004	Firehouse #10 (roof level)	5/24/07	1769.2	Metals	6020	STL-SAC	5/26/07	3.0	67.6	< 0.68	< 0.68	9.4	61.6	26.8	63.8	12.4	161	No	No		
METALS-ST10-5/24/07	G7E260194005	North Side Sidewalk Bridge	5/24/07	1753.1	Metals	6020	STL-SAC	5/26/07	2.7	< 68.4	< 0.68	< 0.68	10.7	53.5	23.6	63.0	11.6	138	No	No		
METALS-ST11-5/24/07	G7E260194006	90 Trinity Place (roof level)	5/24/07	1788.9	Metals	6020	STL-SAC	5/26/07	1.9	< 67.1	< 0.67	< 0.67	< 6.7	49.0	16.9	26.1	6.7	59.5	No	No		
METALS-ST12-5/24/07	G7E260194007	110 Greenwich Street (roof level)	5/24/07	1789.4	Metals	6020	STL-SAC	5/26/07	1.9	< 67.1	< 0.67	< 0.67	< 6.7	41.6	16.5	24.0	6.5	56.6	No	No		
METALS-ST13-5/24/07	G7E260194008	Marriot Hotel, 38th Floor (roof level)	5/24/07	1787.8	Metals	6020	STL-SAC	5/26/07	1.7	< 67.1	< 0.67	< 0.67	< 6.7	55.7	16.0	6.8	24.0	6.8	67.2	No	No	
METALS-ST14-5/24/07	G7E260194009	West Face - South end at corner (scaffolding level)	5/24/07	1803	Metals	6020	STL-SAC	5/26/07	2.0	< 66.6	< 0.66	< 0.66	< 6.6	55.4	16.1	24.2	6.9	64.0	No	No		
METALS-ST15-5/24/07	G7E260194010	South Face - East end at corner (scaffolding level)	5/24/07	1814.9	Metals	6020	STL-SAC	5/26/07	1.9	< 66.1	< 0.66	< 0.66	< 6.6	50.6	15.4	25.3	7.1	65.7	No	No		
METALS-ST16-5/24/07	G7E260194011	East Face - North end at corner (scaffolding level)	5/24/07	1791.2	Metals	6020	STL-SAC	5/26/07	2.6	< 67.0	< 0.67	< 0.67	< 6.7	93.5	18.4	36.1	8.5	84.4	No	No		
METALS-ST17-5/24/07	G7E260194012	North Face - West end at corner (scaffolding level)	5/24/07	1814.3	Metals	6020	STL-SAC	5/26/07	1.9	< 66.1	< 0.66	< 0.66	< 6.7	45.5	17.3	33.6	7.2	81.8	No	No		