

| TRC Field Sample No.                    | Sample No.     | Sampling Location                                   | Collection Start Date | Work Shift | Sample Volume (m <sup>3</sup> ) | Analyte  | Analytical Method | Lab  | Lab Sample Receipt Date | Asbestos PCME Concentration (f/cm3) | Exceeds Target Air Quality Levels | Exceeds EPA Site Specific Trigger Levels | Comments |
|---|----------------|---|-----------------------|------------|---------------------------------|----------|-------------------|------|-------------------------|-------------------------------------|-----------------------------------|--|----------|
| <b>Target Air Quality Levels</b>        |                |   |                       |            |                                 |          |                   |      |                         | <b>0.0009</b>                       |                                   |  |          |
| <b>EPA Site Specific Trigger Levels</b> |                |   |                       |            |                                 |          |                   |      |                         | <b>NA</b>                           |                                   |  |          |
| ASBESTOS-ST1-1/5/09                     | 030900391-0001 | Southwest Area (sidewalk bridge level)              | 1/5/09                | 1          | 3.070                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00080                           | No                                | No                                       |          |
| ASBESTOS-ST2-1/5/09                     | 030900391-0002 | Southeast Area (sidewalk bridge level)              | 1/5/09                | 1          | 3.110                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00079                           | No                                | No                                       |          |
| ASBESTOS-ST4-1/5/09                     | 030900391-0003 | Northwest Area (street-level)                       | 1/5/09                | 1          | 3.070                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00080                           | No                                | No                                       |          |
| ASBESTOS-ST5-1/5/09                     | 030900391-0004 | Firehouse #10 (roof level)                          | 1/5/09                | 1          | 3.050                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST10-1/5/09                    | 030900391-0005 | North Side Sidewalk Bridge                          | 1/5/09                | 1          | 3.020                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST11-1/5/09                    | 030900391-0006 | 90 Trinity Place (roof level)                       | 1/5/09                | 1          | 3.060                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST12-1/5/09                    | 030900391-0007 | 110 Greenwich Street (roof level)                   | 1/5/09                | 1          | 3.120                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00079                           | No                                | No                                       |          |
| ASBESTOS-ST13-1/5/09                    | 030900391-0008 | Marriott Hotel, 38th Floor (roof level)             | 1/5/09                | 1          | 2.990                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00083                           | No                                | No                                       |          |
| ASBESTOS-ST14-1/5/09                    | 030900391-0009 | West Face - South end at corner (scaffolding level) | 1/5/09                | 1          | 3.060                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST15-1/5/09                    | 030900391-0010 | South Face - East end at corner (scaffolding level) | 1/5/09                | 1          | 3.050                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST16-1/5/09                    | 030900391-0011 | East Face - North end at corner (scaffolding level) | 1/5/09                | 1          | 2.980                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00083                           | No                                | No                                       |          |
| ASBESTOS-ST17-1/5/09                    | 030900391-0012 | North Face - West end at corner (scaffolding level) | 1/5/09                | 1          | 3.090                           | Asbestos | PCME              | EMSL | 1/6/09                  | < 0.00080                           | No                                | No                                       |          |