

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										0.0009			
EPA Site Specific Trigger Levels										NA			
ASBESTOS-ST1-2/4/09	030903400-0001	Southwest Area (sidewalk bridge level)	2/4/09	1	3.060	Asbestos	PCME	EMSL	2/5/09	< 0.00081	No	No	
ASBESTOS-ST2-2/4/09	030903400-0002	Southeast Area (sidewalk bridge level)	2/4/09	1	3.100	Asbestos	PCME	EMSL	2/5/09	< 0.00080	No	No	
ASBESTOS-ST4-2/4/09	030903400-0003	Northwest Area (street-level)	2/4/09	1	2.950	Asbestos	PCME	EMSL	2/5/09	< 0.00084	No	No	
ASBESTOS-ST5-2/4/09	030903400-0004	Firehouse #10 (roof level)	2/4/09	1	3.050	Asbestos	PCME	EMSL	2/5/09	< 0.00081	No	No	
ASBESTOS-ST10-2/4/09	030903400-0005	North Side Sidewalk Bridge	2/4/09	1	3.070	Asbestos	PCME	EMSL	2/5/09	< 0.00080	No	No	
ASBESTOS-ST11-2/4/09	030903400-0006	90 Trinity Place (roof level)	2/4/09	1	3.090	Asbestos	PCME	EMSL	2/5/09	< 0.00080	No	No	
ASBESTOS-ST12-2/4/09	030903400-0007	110 Greenwich Street (roof level)	2/4/09	1	3.060	Asbestos	PCME	EMSL	2/5/09	< 0.00081	No	No	
ASBESTOS-ST13-2/4/09	030903400-0008	Marriott Hotel, 38th Floor (roof level)	2/4/09	1	3.050	Asbestos	PCME	EMSL	2/5/09	< 0.00081	No	No	
ASBESTOS-ST14-2/4/09	030903400-0009	West Face - South end at corner (scaffolding level)	2/4/09	1	3.080	Asbestos	PCME	EMSL	2/5/09	< 0.00080	No	No	
ASBESTOS-ST15-2/4/09	030903400-0010	South Face - East end at corner (scaffolding level)	2/4/09	1	2.990	Asbestos	PCME	EMSL	2/5/09	< 0.00083	No	No	
ASBESTOS-ST16-2/4/09	030903400-0011	East Face - North end at corner (scaffolding level)	2/4/09	1	2.980	Asbestos	PCME	EMSL	2/5/09	< 0.00083	No	No	
ASBESTOS-ST13-2/5/09	030903491-0008	North Face - West end at corner (scaffolding level)	2/4/09	1	2.970	Asbestos	PCME	EMSL	2/5/09	< 0.00083	No	No	
ASBESTOS-ST1-2/5/09	030903491-0001	Southwest Area (sidewalk bridge level)	2/5/09	1	3.080	Asbestos	PCME	EMSL	2/6/09	< 0.00080	No	No	
ASBESTOS-ST2-2/5/09	030903491-0002	Southeast Area (sidewalk bridge level)	2/5/09	1	3.090	Asbestos	PCME	EMSL	2/6/09	< 0.00080	No	No	
ASBESTOS-ST4-2/5/09	030903491-0003	Northwest Area (street-level)	2/5/09	1	3.050	Asbestos	PCME	EMSL	2/6/09	< 0.00081	No	No	
ASBESTOS-ST5-2/5/09	030903491-0004	Firehouse #10 (roof level)	2/5/09	1	3.080	Asbestos	PCME	EMSL	2/6/09	< 0.00080	No	No	
ASBESTOS-ST10-2/5/09	030903491-0005	North Side Sidewalk Bridge	2/5/09	1	3.050	Asbestos	PCME	EMSL	2/6/09	< 0.00081	No	No	
ASBESTOS-ST11-2/5/09	030903491-0006	90 Trinity Place (roof level)	2/5/09	1	2.980	Asbestos	PCME	EMSL	2/6/09	< 0.00083	No	No	
ASBESTOS-ST12-2/5/09	030903491-0007	110 Greenwich Street (roof level)	2/5/09	1	2.950	Asbestos	PCME	EMSL	2/6/09	< 0.00084	No	No	
ASBESTOS-ST13-2/5/09	030903491-0008	Marriott Hotel, 38th Floor (roof level)	2/5/09	1	3.230	Asbestos	PCME	EMSL	2/6/09	< 0.00076	No	No	
ASBESTOS-ST14-2/5/09	030903491-0009	West Face - South end at corner (scaffolding level)	2/5/09	1	3.100	Asbestos	PCME	EMSL	2/6/09	< 0.00080	No	No	
ASBESTOS-ST15-2/5/09	030903491-0010	South Face - East end at corner (scaffolding level)	2/5/09	1	3.010	Asbestos	PCME	EMSL	2/6/09	< 0.00082	No	No	
ASBESTOS-ST16-2/5/09	030903491-0011	East Face - North end at corner (scaffolding level)	2/5/09	1	2.960	Asbestos	PCME	EMSL	2/6/09	< 0.00083	No	No	
ASBESTOS-ST17-2/5/09	030903491-0012	North Face - West end at corner (scaffolding level)	2/5/09	1	3.050	Asbestos	PCME	EMSL	2/6/09	< 0.00081	No	No	
ASBESTOS-ST1-2/6/09	030903551-0001	Southwest Area (sidewalk bridge level)	2/6/09	1	3.090	Asbestos	PCME	EMSL	2/7/09	< 0.00080	No	No	
ASBESTOS-ST2-2/6/09	030903551-0002	Southeast Area (sidewalk bridge level)	2/6/09	1	3.090	Asbestos	PCME	EMSL	2/7/09	< 0.00080	No	No	
ASBESTOS-ST4-2/6/09	030903551-0003	Northwest Area (street-level)	2/6/09	1	3.070	Asbestos	PCME	EMSL	2/7/09	< 0.00080	No	No	
ASBESTOS-ST5-2/6/09	030903551-0004	Firehouse #10 (roof level)	2/6/09	1	3.060	Asbestos	PCME	EMSL	2/7/09	< 0.00081	No	No	
ASBESTOS-ST10-2/6/09	030903551-0005	North Side Sidewalk Bridge	2/6/09	1	3.110	Asbestos	PCME	EMSL	2/7/09	< 0.00079	No	No	
ASBESTOS-ST11-2/6/09	030903551-0006	90 Trinity Place (roof level)	2/6/09	1	2.990	Asbestos	PCME	EMSL	2/7/09	< 0.00083	No	No	
ASBESTOS-ST12-2/6/09	030903551-0007	110 Greenwich Street (roof level)	2/6/09	1	2.950	Asbestos	PCME	EMSL	2/7/09	< 0.00084	No	No	
ASBESTOS-ST13-2/6/09	030903551-0008	Marriott Hotel, 38th Floor (roof level)	2/6/09	1	3.040	Asbestos	PCME	EMSL	2/7/09	< 0.00081	No	No	
ASBESTOS-ST14-2/6/09	030903551-0009	West Face - South end at corner (scaffolding level)	2/6/09	1	2.920	Asbestos	PCME	EMSL	2/7/09	< 0.00085	No	No	
ASBESTOS-ST15-2/6/09	030903551-0010	South Face - East end at corner (scaffolding level)	2/6/09	1	2.870	Asbestos	PCME	EMSL	2/7/09	< 0.00086	No	No	
ASBESTOS-ST16-2/6/09	030903551-0011	East Face - North end at corner (scaffolding level)	2/6/09	1	2.910	Asbestos	PCME	EMSL	2/7/09	< 0.00085	No	No	
ASBESTOS-ST17-2/6/09	030903551-0012	North Face - West end at corner (scaffolding level)	2/6/09	1	2.950	Asbestos	PCME	EMSL	2/7/09	< 0.00084	No	No	
ASBESTOS-ST1-2/7/09	030903718-0001	Southwest Area (sidewalk bridge level)	2/7/09	1	3.050	Asbestos	PCME	EMSL	2/9/09	< 0.00081	No	No	
ASBESTOS-ST2-2/7/09	030903718-0002	Southeast Area (sidewalk bridge level)	2/7/09	1	3.120	Asbestos	PCME	EMSL	2/9/09	< 0.00079	No	No	
ASBESTOS-ST4-2/7/09	030903718-0003	Northwest Area (street-level)	2/7/09	1	3.040	Asbestos	PCME	EMSL	2/9/09	< 0.00081	No	No	
ASBESTOS-ST5-2/7/09	030903718-0004	Firehouse #10 (roof level)	2/7/09	1	3.050	Asbestos	PCME	EMSL	2/9/09	< 0.00081	No	No	
ASBESTOS-ST10-2/7/09	030903718-0005	North Side Sidewalk Bridge	2/7/09	1	3.090	Asbestos	PCME	EMSL	2/9/09	< 0.00080	No	No	
ASBESTOS-ST11-2/7/09	030903718-0006	90 Trinity Place (roof level)	2/7/09	1	2.980	Asbestos	PCME	EMSL	2/9/09	< 0.00083	No	No	
ASBESTOS-ST12-2/7/09	030903718-0007	110 Greenwich Street (roof level)	2/7/09	1	2.960	Asbestos	PCME	EMSL	2/9/09	< 0.00083	No	No	
ASBESTOS-ST13-2/7/09	030903718-0008	Marriott Hotel, 38th Floor (roof level)	2/7/09	1	3.050	Asbestos	PCME	EMSL	2/9/09	< 0.00081	No	No	
ASBESTOS-ST14-2/7/09	030903718-0009	West Face - South end at corner (scaffolding level)	2/7/09	1	2.960	Asbestos	PCME	EMSL	2/9/09	< 0.00077	No	No	
ASBESTOS-ST15-2/7/09	030903718-0010	South Face - East end at corner (scaffolding level)	2/7/09	1	3.090	Asbestos	PCME	EMSL	2/9/09	< 0.00080	No	No	
ASBESTOS-ST16-2/7/09	030903718-0011	East Face - North end at corner (scaffolding level)	2/7/09	1	3.050	Asbestos	PCME	EMSL	2/9/09	< 0.00081	No	No	
ASBESTOS-ST17-2/7/09	030903718-0012	North Face - West end at corner (scaffolding level)	2/7/09	1	3.000	Asbestos	PCME	EMSL	2/9/09	< 0.00082	No	No	
ASBESTOS-ST1-2/8/09	030903712-0001	Southwest Area (sidewalk bridge level)	2/8/09	1	3.110	Asbestos	PCME	EMSL	2/9/09	< 0.00079	No	No	
ASBESTOS-ST2-2/8/09	030903712-0002	Southeast Area (sidewalk bridge level)	2/8/09	1	3.150	Asbestos	PCME	EMSL	2/9/09	< 0.00078	No	No	
ASBESTOS-ST4-2/8/09	030903712-0003	Northwest Area (street-level)	2/8/09	1	3.070	Asbestos	PCME	EMSL	2/9/09	< 0.00080	No	No	
ASBESTOS-ST5-2/8/09	030903712-0004	Firehouse #10 (roof level)	2/8/09	1	3.150	Asbestos	PCME	EMSL	2/9/09	< 0.00078	No	No	
ASBESTOS-ST10-2/8/09	030903712-0005	North Side Sidewalk Bridge	2/8/09	1	3.020	Asbestos	PCME	EMSL	2/9/09	< 0.00082	No	No	
ASBESTOS-ST11-2/8/09	030903712-0006	90 Trinity Place (roof level)	2/8/09	1	3.030	Asbestos	PCME	EMSL	2/9/09	< 0.00081	No	No	
ASBESTOS-ST12-2/8/09	030903712-0007	110 Greenwich Street (roof level)	2/8/09	1	3.050	Asbestos	PCME	EMSL	2/9/09	< 0.00081	No	No	
ASBESTOS-ST13-2/8/09	030903712-0008	Marriott Hotel, 38th Floor (roof level)	2/8/09	1	3.100	Asbestos	PCME	EMSL	2/9/09	< 0.00080	No	No	
ASBESTOS-ST14-2/8/09	030903712-0009	West Face - South end at corner (scaffolding level)	2/8/09	1	3.310	Asbestos	PCME	EMSL	2/9/09	< 0.00075	No	No	
ASBESTOS-ST15-2/8/09	030903712-0010	South Face - East end at corner (scaffolding level)	2/8/09	1	3.320	Asbestos	PCME	EMSL	2/9/09	< 0.00074	No	No	
ASBESTOS-ST16-2/8/09	030903712-0011	East Face - North end at corner (scaffolding level)	2/8/09	1	3.230	Asbestos	PCME	EMSL	2/9/09	< 0.00076	No	No	
ASBESTOS-ST17-2/8/09	030903712-0012	North Face - West end at corner (scaffolding level)	2/8/09	1	3.210	Asbestos	PCME	EMSL	2/9/09	< 0.00077	No	No	