

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
<b>Target Air Quality Levels</b>										<b>0.0009</b>			
<b>EPA Site Specific Trigger Levels</b>										<b>NA</b>			
ASBESTOS-ST1-2/11/09	030904070-0001	Southwest Area (sidewalk bridge level)	2/11/09	1	2.150	Asbestos	PCME	EMSL	2/13/09	< 0.00086	No	No	Note 1
ASBESTOS-ST2-2/11/09	030904070-0002	Southeast Area (sidewalk bridge level)	2/11/09	1	3.060	Asbestos	PCME	EMSL	2/13/09	< 0.00081	No	No	
ASBESTOS-ST4-2/11/09	030904070-0003	Northwest Area (street-level)	2/11/09	1	3.050	Asbestos	PCME	EMSL	2/13/09	< 0.00081	No	No	
ASBESTOS-ST5-2/11/09	030904070-0004	Firehouse #10 (roof level)	2/11/09	1	2.980	Asbestos	PCME	EMSL	2/13/09	< 0.00083	No	No	
ASBESTOS-ST10-2/11/09	030904070-0005	North Side Sidewalk Bridge	2/11/09	1	3.040	Asbestos	PCME	EMSL	2/13/09	< 0.00081	No	No	
ASBESTOS-ST11-2/11/09	030904070-0006	90 Trinity Place (roof level)	2/11/09	1	3.010	Asbestos	PCME	EMSL	2/13/09	< 0.00082	No	No	
ASBESTOS-ST12-2/11/09	030904070-0007	110 Greenwich Street (roof level)	2/11/09	1	2.910	Asbestos	PCME	EMSL	2/13/09	< 0.00085	No	No	
ASBESTOS-ST13-2/11/09	030904070-0008	Marriott Hotel, 38th Floor (roof level)	2/11/09	1	3.020	Asbestos	PCME	EMSL	2/13/09	< 0.00082	No	No	
ASBESTOS-ST14-2/11/09	030904128-0001	West Face - South end at corner (scaffolding level)	2/11/09	1	6.110	Asbestos	PCME	EMSL	2/13/09	< 0.00081	No	No	Note 2
ASBESTOS-ST15-2/11/09	030904128-0002	South Face - East end at corner (scaffolding level)	2/11/09	1	6.080	Asbestos	PCME	EMSL	2/13/09	< 0.00081	No	No	Note 2
ASBESTOS-ST16-2/11/09	030904128-0003	East Face - North end at corner (scaffolding level)	2/11/09	1	5.990	Asbestos	PCME	EMSL	2/13/09	< 0.00082	No	No	Note 2
ASBESTOS-ST17-2/11/09	030904128-0004	North Face - West end at corner (scaffolding level)	2/11/09	1	5.910	Asbestos	PCME	EMSL	2/13/09	< 0.00084	No	No	Note 2
ASBESTOS-ST1-2/12/09	030904130-0001	Southwest Area (sidewalk bridge level)	2/12/09	1	3.160	Asbestos	PCME	EMSL	2/13/09	< 0.00078	No	No	
ASBESTOS-ST2-2/12/09	030904130-0002	Southeast Area (sidewalk bridge level)	2/12/09	1	3.080	Asbestos	PCME	EMSL	2/13/09	< 0.00080	No	No	
ASBESTOS-ST4-2/12/09	030904130-0003	Northwest Area (street-level)	2/12/09	1	3.040	Asbestos	PCME	EMSL	2/13/09	< 0.00081	No	No	
ASBESTOS-ST5-2/12/09	030904130-0004	Firehouse #10 (roof level)	2/12/09	1	3.080	Asbestos	PCME	EMSL	2/13/09	< 0.00080	No	No	
ASBESTOS-ST10-2/12/09	030904130-0005	North Side Sidewalk Bridge	2/12/09	1	3.020	Asbestos	PCME	EMSL	2/13/09	< 0.00082	No	No	
ASBESTOS-ST11-2/12/09	030904130-0006	90 Trinity Place (roof level)	2/12/09	1	3.090	Asbestos	PCME	EMSL	2/13/09	< 0.00080	No	No	
ASBESTOS-ST12-2/12/09	030904130-0007	110 Greenwich Street (roof level)	2/12/09	1	3.050	Asbestos	PCME	EMSL	2/13/09	< 0.00081	No	No	
ASBESTOS-ST13-2/12/09	030904130-0008	Marriott Hotel, 38th Floor (roof level)	2/12/09	1	3.010	Asbestos	PCME	EMSL	2/13/09	< 0.00082	No	No	

Note:

- The asbestos sample at Station 1(Southwest Area [sidewalk bridge level]) on February 11, 2009 had a reduced volume due to a temporary power outage.
- The asbestos sample volumes at Station 14 (West Face - South end at corner [scaffolding level]), Station 15 [South Face - East end at corner [scaffolding level]], Station 16 (East Face - North end at corner [scaffolding level]), and Station 17 (North Face - West end at corner [scaffolding level]) on February 11, 2009 represent 2 consecutive 24-hour periods as samples could not be retrieved on February 12, 2009 due to hazardous conditions on the scaffolding posed by high winds.
- Asbestos samples at Station 14 (West Face - South end at corner [scaffolding level]), Station 15 [South Face - East end at corner [scaffolding level]], Station 16 (East Face - North end at corner [scaffolding level]), and Station 17 (North Face - West end at corner [scaffolding level]) on February 12, 2009 were not accessible due to hazardous conditions on the scaffolding posed by high winds. Refer to samples collected on February 11, 2009 which reflect 2 consecutive 24-hour periods.