

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										0.0009	Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	
										NA			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-2/16/06	030605080-0001	Southwest Area (sidewalk bridge level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST2-2/16/06	030605080-0002	Southeast Area (sidewalk bridge level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST4-2/16/05	030605080-0003	Northwest Area (street-level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST5-2/16/06	030605080-0004	Firehouse #10 (roof level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST10-2/16/06	030605080-0005	North Side Sidewalk Bridge	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST11-2-16/06	030605080-0006	90 Trinity Place (roof level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST12-2/16/06	030605080-0007	110 Greenwich Street (roof level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST13-2/16/06	030605080-0008	Marriott Hotel, 38th Floor (roof level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST14-2/16/06	030605080-0009	West Face - South end at corner (scaffolding level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST15-2/16/06	030605080-0010	South Face - East end at corner (scaffolding level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST16-2/16/06	030605080-0011	East Face - North end at corner (scaffolding level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	
ASBESTOS-ST17-2/16/06	030605080-0012	North Face - West end at corner (scaffolding level)	2/16/06	1	2.970	Asbestos	PCME	EMSL	2/17/06	< 0.00083	No	No	