

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										0.0009	Air Quality Levels	Site Specific Trigger Levels	
										NA			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-3/20/07	030708632-0001	Southwest Area (sidewalk bridge level)	3/20/07	1	2.840	Asbestos	PCME	EMSL	3/21/07	< 0.00080	No	No	
ASBESTOS-ST2-3/20/07	030708632-0002	Southeast Area (sidewalk bridge level)	3/20/07	1	3.020	Asbestos	PCME	EMSL	3/21/07	< 0.00082	No	No	
ASBESTOS-ST5-3/20/07	030708632-0003	Firehouse #10 (roof level)	3/20/07	1	3.020	Asbestos	PCME	EMSL	3/21/07	< 0.00082	No	No	
ASBESTOS-ST10-3/20/07	030708632-0004	North Side Sidewalk Bridge	3/20/07	1	3.120	Asbestos	PCME	EMSL	3/21/07	< 0.00079	No	No	
ASBESTOS-ST11-3/20/07	030708632-0005	90 Trinity Place (roof level)	3/20/07	1	3.010	Asbestos	PCME	EMSL	3/21/07	< 0.00082	No	No	
ASBESTOS-ST12-3/20/07	030708632-0006	110 Greenwich Street (roof level)	3/20/07	1	3.010	Asbestos	PCME	EMSL	3/21/07	< 0.00082	No	No	
ASBESTOS-ST13-3/20/07	030708632-0007	Marriott Hotel, 38th Floor (roof level)	3/20/07	1	3.020	Asbestos	PCME	EMSL	3/21/07	< 0.00082	No	No	
ASBESTOS-ST14-3/20/07	030708632-0008	West Face - South end at corner (scaffolding level)	3/20/07	1	3.020	Asbestos	PCME	EMSL	3/21/07	< 0.00082	No	No	
ASBESTOS-ST15-3/20/07	030708632-0009	South Face - East end at corner (scaffolding level)	3/20/07	1	3.220	Asbestos	PCME	EMSL	3/21/07	< 0.00077	No	No	
ASBESTOS-ST16-3/20/07	030708632-0010	East Face - North end at corner (scaffolding level)	3/20/07	1	3.060	Asbestos	PCME	EMSL	3/21/07	< 0.00081	No	No	
ASBESTOS-ST17-3/20/07	030708632-0011	North Face - West end at corner (scaffolding level)	3/20/07	1	3.020	Asbestos	PCME	EMSL	3/21/07	< 0.00082	No	No	

Note:

- Asbestos sample at Station 4 (Northwest Area [street level]) on March 20, 2007 was not available for analysis on account of sample loss.