

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										0.0009			
										NA			
ASBESTOS-ST1-3/23/09	030907561-0001	Southwest Area (sidewalk bridge level)	3/23/09	1	3.100	Asbestos	PCME	EMSL	3/24/09	< 0.00087	No	No	
ASBESTOS-ST2-3/23/09	030907561-0002	Southeast Area (sidewalk bridge level)	3/23/09	1	3.030	Asbestos	PCME	EMSL	3/24/09	< 0.00081	No	No	
ASBESTOS-ST4-3/23/09	030907561-0003	Northwest Area (street-level)	3/23/09	1	3.040	Asbestos	PCME	EMSL	3/24/09	< 0.00081	No	No	
ASBESTOS-ST5-3/23/09	030907561-0004	Firehouse #10 (roof level)	3/23/09	1	3.020	Asbestos	PCME	EMSL	3/24/09	< 0.00082	No	No	
ASBESTOS-ST10-3/23/09	030907561-0005	North Side Sidewalk Bridge	3/23/09	1	3.080	Asbestos	PCME	EMSL	3/24/09	< 0.00080	No	No	
ASBESTOS-ST100-3/23/09	030907561-0013	Station 10 Field Duplicate	3/23/09	1	2.980	Asbestos	PCME	EMSL	3/24/09	< 0.00083	No	No	
ASBESTOS-ST11-3/23/09	030907561-0006	90 Trinity Place (roof level)	3/23/09	1	2.990	Asbestos	PCME	EMSL	3/24/09	< 0.00083	No	No	
ASBESTOS-ST12-3/23/09	030907561-0007	110 Greenwich Street (roof level)	3/23/09	1	3.100	Asbestos	PCME	EMSL	3/24/09	< 0.00080	No	No	
ASBESTOS-ST13-3/23/09	030907561-0008	Marriott Hotel, 38th Floor (roof level)	3/23/09	1	3.040	Asbestos	PCME	EMSL	3/24/09	< 0.00081	No	No	
ASBESTOS-ST14-3/23/09	030907561-0009	West Face - South end at corner (scaffolding level)	3/23/09	1	2.860	Asbestos	PCME	EMSL	3/24/09	< 0.00080	No	No	
ASBESTOS-ST15-3/23/09	030907561-0010	South Face - East end at corner (scaffolding level)	3/23/09	1	2.840	Asbestos	PCME	EMSL	3/24/09	< 0.00080	No	No	
ASBESTOS-ST16-3/23/09	030907561-0011	East Face - North end at corner (scaffolding level)	3/23/09	1	2.830	Asbestos	PCME	EMSL	3/24/09	< 0.00080	No	No	
ASBESTOS-ST17-3/23/09	030907561-0012	North Face - West end at corner (scaffolding level)	3/23/09	1	1.750	Asbestos	PCME	EMSL	3/24/09	< 0.00085	No	No	
ASBESTOS-ST1-3/24/09	030907672-0001	Southwest Area (sidewalk bridge level)	3/24/09	1	3.170	Asbestos	PCME	EMSL	3/25/09	< 0.00085	No	No	
ASBESTOS-ST2-3/24/09	030907672-0002	Southeast Area (sidewalk bridge level)	3/24/09	1	3.110	Asbestos	PCME	EMSL	3/25/09	< 0.00087	No	No	
ASBESTOS-ST4-3/24/09	030907672-0003	Northwest Area (street-level)	3/24/09	1	3.010	Asbestos	PCME	EMSL	3/25/09	< 0.00082	No	No	
ASBESTOS-ST5-3/24/09	030907672-0004	Firehouse #10 (roof level)	3/24/09	1	2.980	Asbestos	PCME	EMSL	3/25/09	< 0.00083	No	No	
ASBESTOS-ST10-3/24/09	030907672-0005	North Side Sidewalk Bridge	3/24/09	1	3.150	Asbestos	PCME	EMSL	3/25/09	< 0.00085	No	No	
ASBESTOS-ST11-3/24/09	030907672-0006	90 Trinity Place (roof level)	3/24/09	1	3.070	Asbestos	PCME	EMSL	3/25/09	< 0.00088	No	No	
ASBESTOS-ST12-3/24/09	030907672-0007	110 Greenwich Street (roof level)	3/24/09	1	2.960	Asbestos	PCME	EMSL	3/25/09	< 0.00083	No	No	
ASBESTOS-ST13-3/24/09	030907672-0008	Marriott Hotel, 38th Floor (roof level)	3/24/09	1	3.050	Asbestos	PCME	EMSL	3/25/09	< 0.00081	No	No	
ASBESTOS-ST14-3/24/09	030907672-0009	West Face - South end at corner (scaffolding level)	3/24/09	1	3.010	Asbestos	PCME	EMSL	3/25/09	< 0.00082	No	No	
ASBESTOS-ST15-3/24/09	030907672-0010	South Face - East end at corner (scaffolding level)	3/24/09	1	2.940	Asbestos	PCME	EMSL	3/25/09	< 0.00084	No	No	
ASBESTOS-ST16-3/24/09	030907672-0011	East Face - North end at corner (scaffolding level)	3/24/09	1	2.930	Asbestos	PCME	EMSL	3/25/09	< 0.00084	No	No	
ASBESTOS-ST17-3/24/09	030907672-0012	North Face - West end at corner (scaffolding level)	3/24/09	1	2.880	Asbestos	PCME	EMSL	3/25/09	< 0.00086	No	No	

- Note:
- The asbestos sample volumes at Station 14 (West Face - South end at corner [scaffolding level]), Station 15 (South Face - East end at corner [scaffolding level]) and Station 16 (East Face - North end at corner [scaffolding level]) on March 23, 2009 experienced a 110 minute power outage caused by an electrical leg failure.
 - The asbestos sample at Station 17 (North Face - West end at corner [scaffolding level:15th floor]) on March 23, 2009 had a reduced volume due to 650 minute power outage caused by an electrical leg failure.