

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments	
										0.0009	Air Quality Levels	Site Specific Trigger Levels		
										NA				
Target Air Quality Levels														
EPA Site Specific Trigger Levels														
ASBESTOS-ST1-4/27/06	030612802-0001	Southwest Area (sidewalk bridge level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST2-4/27/06	030612802-0002	Southeast Area (sidewalk bridge level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST4-4/27/06	030612802-0003	Northwest Area (street-level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST5-4/27/06	030612802-0004	Firehouse #10 (roof level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST10-4/27/06	030612802-0005	North Side Sidewalk Bridge	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST11-4/27/06	030612802-0006	90 Trinity Place (roof level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST12-4/27/06	030612802-0007	110 Greenwich Street (roof level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST13-4/27/06	030612802-0008	Marriott Hotel, 38th Floor (roof level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST14-4/27/06	030612802-0009	West Face - South end at corner (scaffolding level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST15-4/27/06	030612802-0010	South Face - East end at corner (scaffolding level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST16-4/27/06	030612802-0011	East Face - North end at corner (scaffolding level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		
ASBESTOS-ST17-4/27/06	030612802-0012	North Face - West end at corner (scaffolding level)	4/27/06	1	3.000	Asbestos	PCME	EMSL	4/28/06	< 0.00082	No	No		