

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments	
										0.0009	Air Quality Levels	Site Specific Trigger Levels		
										NA				
Target Air Quality Levels														
EPA Site Specific Trigger Levels														
ASBESTOS-ST1-5/4/09	030911298-0001	Southwest Area (sidewalk bridge level)	5/4/09	1	3.090	Asbestos	PCME	EMSL	5/5/09	< 0.00080	No	No		
ASBESTOS-ST2-5/4/09	030911298-0002	Southeast Area (sidewalk bridge level)	5/4/09	1	3.140	Asbestos	PCME	EMSL	5/5/09	< 0.00079	No	No		
ASBESTOS-ST4-5/4/09	030911298-0003	Northwest Area (street-level)	5/4/09	1	3.050	Asbestos	PCME	EMSL	5/5/09	< 0.00081	No	No		
ASBESTOS-ST5-5/4/09	030911298-0004	Firehouse #10 (roof level)	5/4/09	1	3.040	Asbestos	PCME	EMSL	5/5/09	< 0.00081	No	No		
ASBESTOS-ST10-5/4/09	030911298-0005	North Side Sidewalk Bridge	5/4/09	1	3.000	Asbestos	PCME	EMSL	5/5/09	< 0.00082	No	No		
ASBESTOS-ST100-5/4/09	030911298-0013	Station 10 Field Duplicate	5/4/09	1	3.020	Asbestos	PCME	EMSL	5/5/09	< 0.00082	No	No		
ASBESTOS-ST11-5/4/09	030911298-0006	90 Trinity Place (roof level)	5/4/09	1	3.070	Asbestos	PCME	EMSL	5/5/09	< 0.00080	No	No		
ASBESTOS-ST12-5/4/09	030911298-0007	110 Greenwich Street (roof level)	5/4/09	1	3.010	Asbestos	PCME	EMSL	5/5/09	< 0.00082	No	No		
ASBESTOS-ST13-5/4/09	030911298-0008	Marriott Hotel, 38th Floor (roof level)	5/4/09	1	3.110	Asbestos	PCME	EMSL	5/5/09	< 0.00079	No	No		
ASBESTOS-ST14-5/4/09	030911298-0009	West Face - South end at corner (scaffolding level)	5/4/09	1	2.830	Asbestos	PCME	EMSL	5/5/09	< 0.00080	No	No		
ASBESTOS-ST15-5/4/09	030911298-0010	South Face - East end at corner (scaffolding level)	5/4/09	1	2.780	Asbestos	PCME	EMSL	5/5/09	< 0.00082	No	No	Note 1	
ASBESTOS-ST16-5/4/09	030911298-0011	East Face - North end at corner (scaffolding level)	5/4/09	1	2.720	Asbestos	PCME	EMSL	5/5/09	< 0.00084	No	No		
ASBESTOS-ST17-5/4/09	030911298-0012	North Face - West end at corner (scaffolding level)	5/4/09	1	2.800	Asbestos	PCME	EMSL	5/5/09	< 0.00081	No	No		

Note:

1. The asbestos sample from Station 15 (South Face - East end at corner [scaffolding level]) on May 4, 2009 experienced a 130 minute power outage.