

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										0.0009			
										NA			
ASBESTOS-ST1-5/21/07	030716366-0001	Southwest Area (sidewalk bridge level)	5/21/07	1	3.090	Asbestos	PCME	EMSL	5/22/07	< 0.00080	No	No	
ASBESTOS-ST2-5/21/07	030716366-0002	Southeast Area (sidewalk bridge level)	5/21/07	1	3.090	Asbestos	PCME	EMSL	5/22/07	0.00160	Yes	No	Note 1
ASBESTOS-ST4-5/21/07	030716366-0003	Northwest Area (street-level)	5/21/07	1	3.200	Asbestos	PCME	EMSL	5/22/07	< 0.00077	No	No	
ASBESTOS-ST5-5/21/07	030716366-0004	Firehouse #10 (roof level)	5/21/07	1	3.040	Asbestos	PCME	EMSL	5/22/07	< 0.00081	No	No	
ASBESTOS-ST10-5/21/07	030716366-0005	North Side Sidewalk Bridge	5/21/07	1	3.160	Asbestos	PCME	EMSL	5/22/07	< 0.00078	No	No	
ASBESTOS-ST11-5/21/07	030716366-0006	90 Trinity Place (roof level)	5/21/07	1	2.980	Asbestos	PCME	EMSL	5/22/07	< 0.00083	No	No	
ASBESTOS-ST12-5/21/07	030716366-0007	110 Greenwich Street (roof level)	5/21/07	1	3.060	Asbestos	PCME	EMSL	5/22/07	< 0.00081	No	No	
ASBESTOS-ST13-5/21/07	030716366-0008	Marriott Hotel, 38th Floor (roof level)	5/21/07	1	3.010	Asbestos	PCME	EMSL	5/22/07	< 0.00082	No	No	
ASBESTOS-ST14-5/21/07	030716366-0009	West Face - South end at corner (scaffolding level)	5/21/07	1	3.010	Asbestos	PCME	EMSL	5/22/07	< 0.00082	No	No	
ASBESTOS-ST15-5/21/07	030716366-0010	South Face - East end at corner (scaffolding level)	5/21/07	1	3.020	Asbestos	PCME	EMSL	5/22/07	< 0.00082	No	No	
ASBESTOS-ST16-5/21/07	030716366-0011	East Face - North end at corner (scaffolding level)	5/21/07	1	3.040	Asbestos	PCME	EMSL	5/22/07	< 0.00081	No	No	
ASBESTOS-ST17-5/21/07	030716366-0012	North Face - West end at corner (scaffolding level)	5/21/07	1	3.090	Asbestos	PCME	EMSL	5/22/07	< 0.00080	No	No	
ASBESTOS-ST1-5/22/07	030716513-0001	Southwest Area (sidewalk bridge level)	5/22/07	1	2.950	Asbestos	PCME	EMSL	5/23/07	< 0.00084	No	No	
ASBESTOS-ST2-5/22/07	030716513-0002	Southeast Area (sidewalk bridge level)	5/22/07	1	3.060	Asbestos	PCME	EMSL	5/23/07	< 0.00081	No	No	
ASBESTOS-ST4-5/22/07	030716513-0003	Northwest Area (street-level)	5/22/07	1	2.990	Asbestos	PCME	EMSL	5/23/07	< 0.00083	No	No	
ASBESTOS-ST5-5/22/07	030716513-0004	Firehouse #10 (roof level)	5/22/07	1	3.050	Asbestos	PCME	EMSL	5/23/07	< 0.00081	No	No	
ASBESTOS-ST10-5/22/07	030716513-0005	North Side Sidewalk Bridge	5/22/07	1	3.120	Asbestos	PCME	EMSL	5/23/07	< 0.00079	No	No	
ASBESTOS-ST11-5/22/07	030716513-0006	90 Trinity Place (roof level)	5/22/07	1	3.060	Asbestos	PCME	EMSL	5/23/07	< 0.00081	No	No	
ASBESTOS-ST12-5/22/07	030716513-0007	110 Greenwich Street (roof level)	5/22/07	1	3.030	Asbestos	PCME	EMSL	5/23/07	< 0.00081	No	No	
ASBESTOS-ST13-5/22/07	030716513-0008	Marriott Hotel, 38th Floor (roof level)	5/22/07	1	3.050	Asbestos	PCME	EMSL	5/23/07	0.00081	No	No	
ASBESTOS-ST14-5/22/07	030716513-0009	West Face - South end at corner (scaffolding level)	5/22/07	1	3.070	Asbestos	PCME	EMSL	5/23/07	< 0.00080	No	No	
ASBESTOS-ST15-5/22/07	030716513-0010	South Face - East end at corner (scaffolding level)	5/22/07	1	3.040	Asbestos	PCME	EMSL	5/23/07	< 0.00081	No	No	
ASBESTOS-ST16-5/22/07	030716513-0011	East Face - North end at corner (scaffolding level)	5/22/07	1	3.060	Asbestos	PCME	EMSL	5/23/07	< 0.00081	No	No	
ASBESTOS-ST17-5/22/07	030716513-0012	North Face - West end at corner (scaffolding level)	5/22/07	1	3.070	Asbestos	PCME	EMSL	5/23/07	< 0.00080	No	No	

Note:  
1. The running average for asbestos at Station 2 (Southeast Area [sidewalk bridge level]) from September 14, 2005 through May 21, 2007 is 0.00082 f/cm3, which is below the Target Air Quality Level of 0.0009 f/cm3.