

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										<b>0.0009</b>	Air Quality Levels	Site Specific Trigger Levels	
										<b>NA</b>			
<b>Target Air Quality Levels</b>													
<b>EPA Site Specific Trigger Levels</b>													
ASBESTOS-ST2-7/21/08	030824281-0001	Southeast Area (sidewalk bridge level)	7/21/08	1	3.160	Asbestos	PCME	EMSL	7/22/08	< 0.00078	No	No	
ASBESTOS-ST4-7/21/08	030824281-0002	Northwest Area (street-level)	7/21/08	1	3.110	Asbestos	PCME	EMSL	7/22/08	< 0.00079	No	No	
ASBESTOS-ST5-7/21/08	030824281-0003	Firehouse #10 (roof level)	7/21/08	1	2.920	Asbestos	PCME	EMSL	7/22/08	< 0.00085	No	No	
ASBESTOS-ST10-7/21/08	030824281-0004	North Side Sidewalk Bridge	7/21/08	1	3.170	Asbestos	PCME	EMSL	7/22/08	< 0.00078	No	No	
ASBESTOS-ST11-7/21/08	030824281-0005	90 Trinity Place (roof level)	7/21/08	1	2.990	Asbestos	PCME	EMSL	7/22/08	< 0.00083	No	No	
ASBESTOS-ST12-7/21/08	030824281-0006	110 Greenwich Street (roof level)	7/21/08	1	3.010	Asbestos	PCME	EMSL	7/22/08	< 0.00082	No	No	
ASBESTOS-ST13-7/21/08	030824281-0007	Marriott Hotel, 38th Floor (roof level)	7/21/08	1	2.990	Asbestos	PCME	EMSL	7/22/08	< 0.00083	No	No	
ASBESTOS-ST14-7/21/08	030824281-0008	West Face - South end at corner (scaffolding level)	7/21/08	1	2.980	Asbestos	PCME	EMSL	7/22/08	< 0.00083	No	No	
ASBESTOS-ST15-7/21/08	030824281-0009	South Face - East end at corner (scaffolding level)	7/21/08	1	2.900	Asbestos	PCME	EMSL	7/22/08	< 0.00085	No	No	
ASBESTOS-ST16-7/21/08	030824281-0010	East Face - North end at corner (scaffolding level)	7/21/08	1	2.590	Asbestos	PCME	EMSL	7/22/08	< 0.00082	No	No	
ASBESTOS-ST17-7/21/08	030824281-0011	North Face - West end at corner (scaffolding level)	7/21/08	1	2.510	Asbestos	PCME	EMSL	7/22/08	< 0.00084	No	No	

Note:

- Asbestos sample at Station 1 (Southwest Area [sidewalk bridge level]) on July 21, 2008 was not available for analysis on account of sample media damage.