

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										0.0009	Air Quality	Exceeds EPA	
										NA	Levels	Site Specific	
												Trigger Levels	
ASBESTOS-ST1-7/26/06	030623698-0001	Southwest Area (sidewalk bridge level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST2-7/26/06	030623698-0002	Southeast Area (sidewalk bridge level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST4-7/26/06	030623698-0003	Northwest Area (street-level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST5-7/26/06	030623698-0004	Firehouse #10 (roof level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST6-7/26/06	030623702-0001	Southwest Area (roof level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST7-7/26/06	030623702-0002	Southeast Area (roof level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST8-7/26/06	030623702-0003	Northeast Area (roof level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST9-7/26/06	030623702-0004	Northwest Area (roof level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	0.00249	Yes	No	Note 1.
ASBESTOS-ST10-7/26/06	030623698-0005	North Side Sidewalk Bridge	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST11-7/26/06	030623698-0006	90 Trinity Place (roof level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST12-7/26/06	030623698-0007	110 Greenwich Street (roof level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST13-7/26/06	030623698-0008	Marriott Hotel, 38th Floor (roof level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST14-7/26/06	030623698-0009	West Face - South end at corner (scaffolding level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST15-7/26/06	030623698-0010	South Face - East end at corner (scaffolding level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST16-7/26/06	030623698-0011	East Face - North end at corner (scaffolding level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	
ASBESTOS-ST17-7/26/06	030623698-0012	North Face - West end at corner (scaffolding level)	7/26/06	1	2.970	Asbestos	PCME	EMSL	7/27/06	< 0.00083	No	No	

Note:

1. Based upon review of the meteorological data in concert with the report of roof cleaning activities it has been determined that the elevated PCME reading on July 26, 2006 at Station 9 (Northwest Area [roof level]) was likely associated with work activities at 130 Liberty Street. The cumulative PCME average for Station 9 reflecting the period July 6, 2006 (start date for monitoring) through July 26, 2006 is 0.00093 F/cm3. Corrective actions that have been instituted include the following: increased use of amended water to wet materials during abatement activities to counter high rate of evaporation due to excessive rooftop temperatures and increased wet misting of work area during abatement operations.