

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										0.0009			
EPA Site Specific Trigger Levels										NA			
ASBESTOS-ST1-7/27/10	031020566-0001	Southwest Area (sidewalk bridge level)	7/27/10	1	3.070	Asbestos	PCME	EMSL	7/28/10	< 0.00080	No	No	
ASBESTOS-ST2-7/27/10	031020566-0002	Southeast Area (sidewalk bridge level)	7/27/10	1	3.150	Asbestos	PCME	EMSL	7/28/10	< 0.00078	No	No	
ASBESTOS-ST4-7/27/10	031020566-0003	Northwest Area (street-level)	7/27/10	1	3.120	Asbestos	PCME	EMSL	7/28/10	< 0.00079	No	No	
ASBESTOS-ST5-7/27/10	031020566-0004	Firehouse #10 (roof level)	7/27/10	1	3.050	Asbestos	PCME	EMSL	7/28/10	< 0.00075	No	No	
ASBESTOS-ST20-7/27/10	031020566-0005	Northeast Area, Sidewalk Bridge	7/27/10	1	3.070	Asbestos	PCME	EMSL	7/28/10	< 0.00074	No	No	
ASBESTOS-ST21-7/27/10	031020566-0007	Marriott Hotel, 4th Floor	7/27/10	1	3.200	Asbestos	PCME	EMSL	7/28/10	< 0.00077	No	No	
ASBESTOS-ST22-7/27/10	031020566-0006	Roof of 120 Cedar Street	7/27/10	1	3.000	Asbestos	PCME	EMSL	7/28/10	< 0.00076	No	No	