

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										0.0009			
										NA			
ASBESTOS-ST1-8/8/09	030920631-0001	Southwest Area (sidewalk bridge level)	8/8/09	1	3.040	Asbestos	PCME	EMSL	8/10/09	< 0.00081	No	No	
ASBESTOS-ST2-8/8/09	030920631-0002	Southeast Area (sidewalk bridge level)	8/8/09	1	3.060	Asbestos	PCME	EMSL	8/10/09	< 0.00081	No	No	
ASBESTOS-ST4-8/8/09	030920631-0003	Northwest Area (street-level)	8/8/09	1	3.030	Asbestos	PCME	EMSL	8/10/09	< 0.00081	No	No	
ASBESTOS-ST5-8/8/09	030920631-0004	Firehouse #10 (roof level)	8/8/09	1	3.020	Asbestos	PCME	EMSL	8/10/09	< 0.00082	No	No	
ASBESTOS-ST10-8/8/09	030920631-0005	North Side Sidewalk Bridge	8/8/09	1	2.940	Asbestos	PCME	EMSL	8/10/09	< 0.00084	No	No	
ASBESTOS-ST11-8/8/09	030920631-0006	90 Trinity Place (roof level)	8/8/09	1	2.970	Asbestos	PCME	EMSL	8/10/09	< 0.00083	No	No	
ASBESTOS-ST12-8/8/09	030920631-0007	110 Greenwich Street (roof level)	8/8/09	1	3.020	Asbestos	PCME	EMSL	8/10/09	< 0.00082	No	No	
ASBESTOS-ST13-8/8/09	030920631-0008	Marriott Hotel, 38th Floor (roof level)	8/8/09	1	3.100	Asbestos	PCME	EMSL	8/10/09	< 0.00080	No	No	
ASBESTOS-ST1-8/9/09	030920629-0001	Southwest Area (sidewalk bridge level)	8/9/09	1	3.210	Asbestos	PCME	EMSL	8/10/09	< 0.00077	No	No	
ASBESTOS-ST2-8/9/09	030920629-0002	Southeast Area (sidewalk bridge level)	8/9/09	1	3.170	Asbestos	PCME	EMSL	8/10/09	< 0.00078	No	No	
ASBESTOS-ST4-8/9/09	030920629-0003	Northwest Area (street-level)	8/9/09	1	3.190	Asbestos	PCME	EMSL	8/10/09	< 0.00077	No	No	
ASBESTOS-ST5-8/9/09	030920629-0004	Firehouse #10 (roof level)	8/9/09	1	3.160	Asbestos	PCME	EMSL	8/10/09	< 0.00078	No	No	
ASBESTOS-ST10-8/9/09	030920629-0005	North Side Sidewalk Bridge	8/9/09	1	3.110	Asbestos	PCME	EMSL	8/10/09	< 0.00079	No	No	
ASBESTOS-ST11-8/9/09	030920629-0006	90 Trinity Place (roof level)	8/9/09	1	3.050	Asbestos	PCME	EMSL	8/10/09	< 0.00081	No	No	
ASBESTOS-ST12-8/9/09	030920629-0007	110 Greenwich Street (roof level)	8/9/09	1	2.980	Asbestos	PCME	EMSL	8/10/09	< 0.00083	No	No	
ASBESTOS-ST13-8/9/09	030920629-0008	Marriott Hotel, 38th Floor (roof level)	8/9/09	1	3.000	Asbestos	PCME	EMSL	8/10/09	< 0.00082	No	No	