

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										0.0009	Air Quality	Exceeds EPA	
										NA	Levels	Site Specific	
												Trigger Levels	
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-8/9/06	030625686-0001	Southwest Area (sidewalk bridge level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST2-8/9/06	030625686-0002	Southeast Area (sidewalk bridge level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST4-8/9/06	030625686-0003	Northwest Area (street-level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST5-8/9/06	030625686-0004	Firehouse #10 (roof level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST6-8/9/06	030625692-0001	Southwest Area (roof level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST7-8/9/06	030625692-0002	Southeast Area (roof level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST8-8/9/06	030625692-0003	Northeast Area (roof level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST9-8/9/06	030625692-0004	Northwest Area (roof level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST10-8/9/06	030625686-0005	North Side Sidewalk Bridge	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST11-8/9/06-	030625686-0006	90 Trinity Place (roof level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST12-8/9/06	030625686-0007	110 Greenwich Street (roof level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST13-8/9/06	030625686-0008	Marriott Hotel, 38th Floor (roof level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST14-8/9/06	030625686-0009	West Face - South end at corner (scaffolding level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST15-8/9/06	030625686-0010	South Face - East end at corner (scaffolding level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST16-8/9/06	030625686-0011	East Face - North end at corner (scaffolding level)	8/9/06	1	2.970	Asbestos	PCME	EMSL	8/10/06	< 0.00083	No	No	
ASBESTOS-ST17-8/9/06	030625686-0012	North Face - West end at corner (scaffolding level)	8/9/06	1	3.020	Asbestos	PCME	EMSL	8/10/06	< 0.00082	No	No	