

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										0.0009			
EPA Site Specific Trigger Levels										NA			
ASBESTOS-ST1-11/29/10	031032738-0001	Southwest Area (sidewalk bridge level)	11/29/10	1	3.020	Asbestos	PCME	EMSL	11/30/10	< 0.00082	No	No	
ASBESTOS-ST2-11/29/10	031032738-0002	Southeast Area (sidewalk bridge level)	11/29/10	1	3.040	Asbestos	PCME	EMSL	11/30/10	< 0.00081	No	No	
ASBESTOS-ST4-11/29/10	031032738-0003	Northwest Area (street-level)	11/29/10	1	3.060	Asbestos	PCME	EMSL	11/30/10	< 0.00081	No	No	
ASBESTOS-ST20-11/29/10	031032738-0004	Northeast Area, Sidewalk Bridge	11/29/10	1	3.010	Asbestos	PCME	EMSL	11/30/10	< 0.00082	No	No	
ASBESTOS-ST1-11/30/10	031032833-0001	Southwest Area (sidewalk bridge level)	11/30/10	1	2.990	Asbestos	PCME	EMSL	12/1/10	0.00083	No	No	
ASBESTOS-ST2-11/30/10	031032833-0002	Southeast Area (sidewalk bridge level)	11/30/10	1	3.050	Asbestos	PCME	EMSL	12/1/10	< 0.00081	No	No	
ASBESTOS-ST4-11/30/10	031032833-0003	Northwest Area (street-level)	11/30/10	1	3.120	Asbestos	PCME	EMSL	12/1/10	< 0.00079	No	No	
ASBESTOS-ST20-11/30/10	031032833-0004	Northeast Area, Sidewalk Bridge	11/30/10	1	3.030	Asbestos	PCME	EMSL	12/1/10	< 0.00081	No	No	