

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										0.0009	Air Quality Levels	Site Specific Trigger Levels	
										NA			
ASBESTOS-ST1-12/14/06	030640433-0001	Southwest Area (sidewalk bridge level)	12/14/06	1	3.030	Asbestos	PCME	EMSL	12/15/06	< 0.00081	No	No	
ASBESTOS-ST2-12/14/06	030640433-0002	Southeast Area (sidewalk bridge level)	12/14/06	1	3.040	Asbestos	PCME	EMSL	12/15/06	< 0.00081	No	No	
ASBESTOS-ST4-12/14/06	030640433-0003	Northwest Area (street-level)	12/14/06	1	2.940	Asbestos	PCME	EMSL	12/15/06	< 0.00084	No	No	
ASBESTOS-ST5-12/14/06	030640433-0004	Firehouse #10 (roof level)	12/14/06	1	3.030	Asbestos	PCME	EMSL	12/15/06	< 0.00081	No	No	
ASBESTOS-ST10-12/14/06	030640433-0005	North Side Sidewalk Bridge	12/14/06	1	3.020	Asbestos	PCME	EMSL	12/15/06	< 0.00082	No	No	
ASBESTOS-ST11-12/14/06	030640433-0006	90 Trinity Place (roof level)	12/14/06	1	2.840	Asbestos	PCME	EMSL	12/15/06	< 0.00087	No	No	
ASBESTOS-ST12-12/14/06	030640433-0007	110 Greenwich Street (roof level)	12/14/06	1	3.090	Asbestos	PCME	EMSL	12/15/06	< 0.00080	No	No	
ASBESTOS-ST13-12/14/06	030640433-0008	Marriott Hotel, 38th Floor (roof level)	12/14/06	1	3.010	Asbestos	PCME	EMSL	12/15/06	< 0.00082	No	No	
ASBESTOS-ST14-12/14/06	030640433-0009	West Face - South end at corner (scaffolding level)	12/14/06	1	3.040	Asbestos	PCME	EMSL	12/15/06	< 0.00081	No	No	
ASBESTOS-ST15-12/14/06	030640433-0010	South Face - East end at corner (scaffolding level)	12/14/06	1	3.030	Asbestos	PCME	EMSL	12/15/06	< 0.00081	No	No	
ASBESTOS-ST16-12/14/06	030640433-0011	East Face - North end at corner (scaffolding level)	12/14/06	1	3.020	Asbestos	PCME	EMSL	12/15/06	< 0.00082	No	No	
ASBESTOS-ST17-12/14/06	030640433-0012	North Face - West end at corner (scaffolding level)	12/14/06	1	2.840	Asbestos	PCME	EMSL	12/15/06	< 0.00087	No	No	