

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										<b>0.0009</b>	Air Quality Levels	Site Specific Trigger Levels	
										<b>NA</b>			
ASBESTOS-ST1-12/19/06	030640994-001	Southwest Area (sidewalk bridge level)	12/19/06	1	3.03	Asbestos	PCME	EMSL	12/20/06	< 0.00081	No	No	
ASBESTOS-ST2-12/19/06	030640994-002	Southeast Area (sidewalk bridge level)	12/19/06	1	3.02	Asbestos	PCME	EMSL	12/20/06	< 0.00082	No	No	
ASBESTOS-ST4-12/19/06	030640994-003	Northwest Area (street-level)	12/19/06	1	3.07	Asbestos	PCME	EMSL	12/20/06	< 0.00080	No	No	
ASBESTOS-ST5-12/19/06	030640994-004	Firehouse #10 (roof level)	12/19/06	1	3.07	Asbestos	PCME	EMSL	12/20/06	< 0.00080	No	No	
ASBESTOS-ST10-12/19/06	030640994-005	North Side Sidewalk Bridge	12/19/06	1	2.92	Asbestos	PCME	EMSL	12/20/06	< 0.00085	No	No	
ASBESTOS-ST11-12/19/06	030640994-006	90 Trinity Place (roof level)	12/19/06	1	2.98	Asbestos	PCME	EMSL	12/20/06	< 0.00083	No	No	
ASBESTOS-ST12-12/19/06	030640994-007	110 Greenwich Street (roof level)	12/19/06	1	3.10	Asbestos	PCME	EMSL	12/20/06	< 0.00080	No	No	
ASBESTOS-ST13-12/19/06	030640994-008	Marriott Hotel, 38th Floor (roof level)	12/19/06	1	3.02	Asbestos	PCME	EMSL	12/20/06	< 0.00082	No	No	
ASBESTOS-ST14-12/19/06	030640994-009	West Face - South end at corner (scaffolding level)	12/19/06	1	3.02	Asbestos	PCME	EMSL	12/20/06	< 0.00082	No	No	
ASBESTOS-ST15-12/19/06	030640994-010	South Face - East end at corner (scaffolding level)	12/19/06	1	3.02	Asbestos	PCME	EMSL	12/20/06	< 0.00082	No	No	
ASBESTOS-ST16-12/19/06	030640994-011	East Face - North end at corner (scaffolding level)	12/19/06	1	3.05	Asbestos	PCME	EMSL	12/20/06	< 0.00081	No	No	
ASBESTOS-ST17-12/19/06	030640994-012	North Face - West end at corner (scaffolding level)	12/19/06	1	3.03	Asbestos	PCME	EMSL	12/20/06	< 0.00081	No	No	