

| TRC Field Sample No.                    | Sample No.     | Sampling Location                                   | Collection Start Date | Work Shift | Sample Volume (m <sup>3</sup> ) | Analyte  | Analytical Method | Lab  | Lab Sample Receipt Date | Asbestos PCME Concentration (f/cm3) | Exceeds Target     | Exceeds EPA                  | Comments |  |
|---|----------------|---|-----------------------|------------|---------------------------------|----------|-------------------|------|-------------------------|-------------------------------------|--------------------|------------------------------|----------|--|
|   |                |   |                       |            |                                 |          |                   |      |                         | <b>0.0009</b>                       | Air Quality Levels | Site Specific Trigger Levels |          |  |
|   |                |   |                       |            |                                 |          |                   |      |                         | <b>NA</b>                           |                    |                              |          |  |
| <b>Target Air Quality Levels</b>        |                |   |                       |            |                                 |          |                   |      |                         |                                     |                    |                              |          |  |
| <b>EPA Site Specific Trigger Levels</b> |                |   |                       |            |                                 |          |                   |      |                         |                                     |                    |                              |          |  |
| ASBESTOS-ST1-12/23/08                   | 030844669-0001 | Southwest Area (sidewalk bridge level)              | 12/23/08              | 1          | 3.050                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00081                           | No                 | No                           |          |  |
| ASBESTOS-ST2-12/23/08                   | 030844669-0002 | Southeast Area (sidewalk bridge level)              | 12/23/08              | 1          | 3.060                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00081                           | No                 | No                           |          |  |
| ASBESTOS-ST4-12/23/08                   | 030844669-0003 | Northwest Area (street-level)                       | 12/23/08              | 1          | 3.000                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00082                           | No                 | No                           |          |  |
| ASBESTOS-ST5-12/23/08                   | 030844669-0004 | Firehouse #10 (roof level)                          | 12/23/08              | 1          | 2.960                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00083                           | No                 | No                           |          |  |
| ASBESTOS-ST10-12/23/08                  | 030844669-0005 | North Side Sidewalk Bridge                          | 12/23/08              | 1          | 2.910                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00085                           | No                 | No                           |          |  |
| ASBESTOS-ST11-12/23/08                  | 030844669-0006 | 90 Trinity Place (roof level)                       | 12/23/08              | 1          | 3.000                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00082                           | No                 | No                           |          |  |
| ASBESTOS-ST12-12/23/08                  | 030844669-0007 | 110 Greenwich Street (roof level)                   | 12/23/08              | 1          | 2.980                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00083                           | No                 | No                           |          |  |
| ASBESTOS-ST13-12/23/08                  | 030844669-0008 | Marriott Hotel, 38th Floor (roof level)             | 12/23/08              | 1          | 3.070                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00088                           | No                 | No                           |          |  |
| ASBESTOS-ST14-12/23/08                  | 030844669-0009 | West Face - South end at corner (scaffolding level) | 12/23/08              | 1          | 2.360                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00084                           | No                 | No                           |          |  |
| ASBESTOS-ST15-12/23/08                  | 030844669-0010 | South Face - East end at corner (scaffolding level) | 12/23/08              | 1          | 2.370                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00083                           | No                 | No                           |          |  |
| ASBESTOS-ST16-12/23/08                  | 030844669-0011 | East Face - North end at corner (scaffolding level) | 12/23/08              | 1          | 2.660                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00074                           | No                 | No                           |          |  |
| ASBESTOS-ST17-12/23/08                  | 030844669-0012 | North Face - West end at corner (scaffolding level) | 12/23/08              | 1          | 2.450                           | Asbestos | PCME              | EMSL | 12/24/08                | < 0.00081                           | No                 | No                           |          |  |