

TRC Field Sample No.	Station Location	Collection Start Date	Collection Time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM10 (ug/m3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
							150			
							150			
PM10-ST1-1/5/2009	Southwest Area (sidewalk bridge level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	28	No	No	
PM10-ST2-1/5/2009	Southeast Area (sidewalk bridge level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	24	No	No	
PM10-ST4-1/5/2009	Northwest Area (street-level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	32	No	No	
PM10-ST5-1/5/2009	Firehouse #10 (roof level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	21	No	No	
PM10-ST10-1/5/2009	North Side Sidewalk Bridge	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	26	No	No	
PM10-ST100-1/5/2009	Station 10 Field Duplicate	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	28	No	No	
PM10-ST11-1/5/2009	90 Trinity Place (roof level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	19	No	No	
PM10-ST12-1/5/2009	110 Greenwich Street (roof level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	17	No	No	
PM10-ST13-1/5/2009	Marriott Hotel, 38th Floor (roof level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	18	No	No	
PM10-ST14-1/5/2009	West Face - South end at corner (scaffolding level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	21	No	No	
PM10-ST15-1/5/2009	South Face - East end at corner (scaffolding level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	25	No	No	
PM10-ST16-1/5/2009	East Face - North end at corner (scaffolding level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	27	No	No	
PM10-ST17-1/5/2009	North Face - West end at corner (scaffolding level)	1/5/09	1440	Particulate	Direct Read	Met One E-BAM	18	No	No	
PM10-ST1-1/6/2009	Southwest Area (sidewalk bridge level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	27	No	No	
PM10-ST2-1/6/2009	Southeast Area (sidewalk bridge level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	25	No	No	
PM10-ST4-1/6/2009	Northwest Area (street-level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	22	No	No	
PM10-ST5-1/6/2009	Firehouse #10 (roof level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	26	No	No	
PM10-ST10-1/6/2009	North Side Sidewalk Bridge	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	20	No	No	
PM10-ST100-1/6/2009	Station 10 Field Duplicate	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	19	No	No	
PM10-ST11-1/6/2009	90 Trinity Place (roof level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	21	No	No	
PM10-ST12-1/6/2009	110 Greenwich Street (roof level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	16	No	No	
PM10-ST13-1/6/2009	Marriott Hotel, 38th Floor (roof level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	17	No	No	
PM10-ST14-1/6/2009	West Face - South end at corner (scaffolding level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	17	No	No	
PM10-ST15-1/6/2009	South Face - East end at corner (scaffolding level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	20	No	No	
PM10-ST16-1/6/2009	East Face - North end at corner (scaffolding level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	21	No	No	
PM10-ST17-1/6/2009	North Face - West end at corner (scaffolding level)	1/6/09	1440	Particulate	Direct Read	Met One E-BAM	13	No	No	