

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Respirable Silica Concentration (ug/m3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
									10			
									10			
SILICA-ST1-2/24/06	040603732-0001	Southwest Area (sidewalk bridge level)	2/24/06	3.69	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST2-2/24/06	040603732-0002	Southeast Area (sidewalk bridge level)	2/24/06	3.7	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST4-2/24/06	040603732-0003	Northwest Area (street-level)	2/24/06	3.66	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST5-2/24/06	040603732-0004	Firehouse #10 (roof level)	2/24/06	3.57	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 6	No	No	
SILICA-ST10-2/24/06	040603732-0005	North Side Sidewalk Bridge	2/24/06	3.68	Silica	NIOSH 7500 XRD	EMSL	2/27/06	1	No	No	
SILICA-ST11-2/24/06	040603732-0006	90 Trinity Place (roof level)	2/24/06	3.57	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST12-2/24/06	040603732-0007	110 Greenwich Street (roof level)	2/24/06	3.77	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST13-2/24/06	040603732-0008	Marriott Hotel, 38th Floor (roof level)	2/24/06	3.79	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST14-2/24/06	040603732-0009	West Face - South end at corner (scaffolding level)	2/24/06	3.35	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST15-2/24/06	040603732-0010	South Face - East end at corner (scaffolding level)	2/24/06	3.36	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST16-2/24/06	040603732-0011	East Face - North end at corner (scaffolding level)	2/24/06	3.42	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST17-2/24/06	040603732-0012	North Face - West end at corner (scaffolding level)	2/24/06	3.37	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST1-2/25/06	040603738-0001	Southwest Area (sidewalk bridge level)	2/25/06	3.62	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST2-2/25/06	040603738-0002	Southeast Area (sidewalk bridge level)	2/25/06	3.64	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST4-2/25/06	040603738-0003	Northwest Area (street-level)	2/25/06	3.59	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST5-2/25/06	040603738-0004	Firehouse #10 (roof level)	2/25/06	3.59	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 6	No	No	
SILICA-ST10-2/25/06	040603738-0005	North Side Sidewalk Bridge	2/25/06	3.61	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST11-2/25/06	040603738-0006	90 Trinity Place (roof level)	2/25/06	3.59	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST12-2/25/06	040603738-0007	110 Greenwich Street (roof level)	2/25/06	3.48	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST13-2/25/06	040603738-0008	Marriott Hotel, 38th Floor (roof level)	2/25/06	3.54	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST1-2/26/06	040603730-0001	Southwest Area (sidewalk bridge level)	2/26/06	3.52	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST2-2/26/06	040603730-0002	Southeast Area (sidewalk bridge level)	2/26/06	3.52	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST4-2/26/06	040603730-0003	Northwest Area (street-level)	2/26/06	3.56	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST5-2/26/06	040603730-0004	Firehouse #10 (roof level)	2/26/06	3.59	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 6	No	No	
SILICA-ST10-2/26/06	040603730-0005	North Side Sidewalk Bridge	2/26/06	3.57	Silica	NIOSH 7500 XRD	EMSL	2/27/06	1	No	No	
SILICA-ST11-2/26/06	040603730-0006	90 Trinity Place (roof level)	2/26/06	3.51	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST12-2/26/06	040603730-0007	110 Greenwich Street (roof level)	2/26/06	3.75	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST13-2/26/06	040603730-0008	Marriott Hotel, 38th Floor (roof level)	2/26/06	3.52	Silica	NIOSH 7500 XRD	EMSL	2/27/06	< 1	No	No	
SILICA-ST1-2/27/06	040603813-0001	Southwest Area (sidewalk bridge level)	2/27/06	3.56	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	
SILICA-ST2-2/27/06	040603813-0002	Southeast Area (sidewalk bridge level)	2/27/06	3.55	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	
SILICA-ST4-2/27/06	040603813-0003	Northwest Area (street-level)	2/27/06	3.61	Silica	NIOSH 7500 XRD	EMSL	2/28/06	2	No	No	
SILICA-ST5-2/27/06	040603813-0004	Firehouse #10 (roof level)	2/27/06	3.53	Silica	NIOSH 7500 XRD	EMSL	2/28/06	1	No	No	
SILICA-ST10-2/27/06	040603813-0005	North Side Sidewalk Bridge	2/27/06	3.61	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	
SILICA-ST100-2/27/06	040603813-0013	Station 10 Field Duplicate	2/27/06	3.6	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	
SILICA-ST11-2/27/06	040603813-0006	90 Trinity Place (roof level)	2/27/06	3.51	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	
SILICA-ST12-2/27/06	040603813-0007	110 Greenwich Street (roof level)	2/27/06	3.42	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	
SILICA-ST13-2/27/06	040603813-0008	Marriott Hotel, 38th Floor (roof level)	2/27/06	3.56	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	
SILICA-ST14-2/27/06	040603813-0009	West Face - South end at corner (scaffolding level)	2/27/06	3.53	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	
SILICA-ST15-2/27/06	040603813-0010	South Face - East end at corner (scaffolding level)	2/27/06	3.52	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	
SILICA-ST16-2/27/06	040603813-0011	East Face - North end at corner (scaffolding level)	2/27/06	3.54	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	
SILICA-ST17-2/27/06	040603813-0012	North Face - West end at corner (scaffolding level)	2/27/06	3.5	Silica	NIOSH 7500 XRD	EMSL	2/28/06	< 1	No	No	

Notes:

1. Silica samples were not available for analysis on February 25 and 26, 2006 at the following locations: Station 14 (West Face - South end at corner [scaffolding level]), Station 15 (South Face - East end at corner [scaffolding level]), Station 16 (East Face - North end at corner [scaffolding level]), and Station 17 (North Face - West end at corner [scaffolding level]). The elevator was out of service on February 26, 2006, rendering the scaffolding stations inaccessible on these dates.