

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Respirable Silica Concentration (ug/m3)	Exceeds Target	Exceeds EPA	Comments
									10	Air Quality Levels	Site Specific Trigger Levels	
Target Air Quality Levels									10			
EPA Site Specific Trigger Levels												
SILICA-ST1-5/31/06	040610882-0001	Southwest Area (sidewalk bridge level)	5/31/06	3.64	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST2-5/31/06	040610882-0002	Southeast Area (sidewalk bridge level)	5/31/06	3.65	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST4-5/31/06	040610882-0003	Northwest Area (street-level)	5/31/06	3.56	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST5-5/31/06	040610882-0004	Firehouse #10 (roof level)	5/31/06	3.6	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST10-5/31/06	040610882-0005	North Side Sidewalk Bridge	5/31/06	3.58	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST11-5/31/06	040610882-0006	90 Trinity Place (roof level)	5/31/06	3.61	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST12-5/31/06	040610882-0007	110 Greenwich Street (roof level)	5/31/06	3.62	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST13-5/31/06	040610882-0008	Marriott Hotel, 38th Floor (roof level)	5/31/06	3.61	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST14-5/31/06	040610882-0009	West Face - South end at corner (scaffolding level)	5/31/06	3.6	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST15-5/31/06	040610882-0010	South Face - East end at corner (scaffolding level)	5/31/06	3.61	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST16-5/31/06	040610882-0011	East Face - North end at corner (scaffolding level)	5/31/06	3.59	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST17-5/31/06	040610882-0012	North Face - West end at corner (scaffolding level)	5/31/06	3.6	Silica	NIOSH 7500 XRD	EMSL	6/1/06	< 1	No	No	
SILICA-ST1-6/1/06	040610972-0001	Southwest Area (sidewalk bridge level)	6/1/06	3.56	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	
SILICA-ST2-6/1/06	040610972-0002	Southeast Area (sidewalk bridge level)	6/1/06	3.56	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 6	No	No	
SILICA-ST4-6/1/06	040610972-0003	Northwest Area (street-level)	6/1/06	3.56	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 6	No	No	
SILICA-ST5-6/1/06	040610972-0004	Firehouse #10 (roof level)	6/1/06	3.57	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	
SILICA-ST10-6/1/06	040610972-0005	North Side Sidewalk Bridge	6/1/06	3.58	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	
SILICA-ST100-6/1/06	040610972-0013	Station 10 Field Duplicate	6/1/06	3.57	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	
SILICA-ST11-6/1/06	040610972-0006	90 Trinity Place (roof level)	6/1/06	3.56	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	
SILICA-ST12-6/1/06	040610972-0007	110 Greenwich Street (roof level)	6/1/06	3.58	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	
SILICA-ST13-6/1/06	040610972-0008	Marriott Hotel, 38th Floor (roof level)	6/1/06	3.58	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	
SILICA-ST14-6/1/06	040610972-0009	West Face - South end at corner (scaffolding level)	6/1/06	3.56	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	
SILICA-ST15-6/1/06	040610972-0010	South Face - East end at corner (scaffolding level)	6/1/06	3.53	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	
SILICA-ST16-6/1/06	040610972-0011	East Face - North end at corner (scaffolding level)	6/1/06	3.57	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	
SILICA-ST17-6/1/06	040610972-0012	North Face - West end at corner (scaffolding level)	6/1/06	3.55	Silica	NIOSH 7500 XRD	EMSL	6/2/06	< 1	No	No	