

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Respirable Silica Concentration (ug/m3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
									10			
									10			
SILICA-ST1-8/8/08	040820696-0001	Southwest Area (sidewalk bridge level)	8/8/08	3.87	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST2-8/8/08	040820696-0002	Southeast Area (sidewalk bridge level)	8/8/08	3.47	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST4-8/8/08	040820696-0003	Northwest Area (street-level)	8/8/08	3.52	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST5-8/8/08	040820696-0004	Firehouse #10 (roof level)	8/8/08	3.67	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST10-8/8/08	040820696-0005	North Side Sidewalk Bridge	8/8/08	3.53	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST11-8/8/08	040820696-0006	90 Trinity Place (roof level)	8/8/08	3.56	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST12-8/8/08	040820696-0007	110 Greenwich Street (roof level)	8/8/08	3.55	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST13-8/8/08	040820696-0008	Marriott Hotel, 38th Floor (roof level)	8/8/08	3.57	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST14(15th) -8/8/08	040820696-0009	West Face - South end at corner (scaffolding level: 15th floor)	8/8/08	3.26	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 2	No	No	
SILICA-ST15(15th) -8/8/08	040820696-0010	South Face - East end at corner (scaffolding level: 15th floor)	8/8/08	3.41	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST16(15th) -8/8/08	040820696-0011	East Face - North end at corner (scaffolding level: 15th floor)	8/8/08	3.4	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST17(15th) -8/8/08	040820696-0012	North Face - West end at corner (scaffolding level: 15th floor)	8/8/08	3.34	Silica	NIOSH 7500 XRD	EMSL	8/9/08	< 1	No	No	
SILICA-ST1-8/9/08	040820778-0001	Southwest Area (sidewalk bridge level)	8/9/08	3.84	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST2-8/9/08	040820778-0002	Southeast Area (sidewalk bridge level)	8/9/08	3.76	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST4-8/9/08	040820778-0003	Northwest Area (street-level)	8/9/08	3.51	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST5-8/9/08	040820778-0004	Firehouse #10 (roof level)	8/9/08	3.57	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST10-8/9/08	040820778-0005	North Side Sidewalk Bridge	8/9/08	3.49	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST11-8/9/08	040820778-0006	90 Trinity Place (roof level)	8/9/08	3.55	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST12-8/9/08	040820778-0007	110 Greenwich Street (roof level)	8/9/08	3.61	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST13-8/9/08	040820778-0008	Marriott Hotel, 38th Floor (roof level)	8/9/08	3.57	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST14(15th) -8/9/08	040820778-0009	West Face - South end at corner (scaffolding level: 15th floor)	8/9/08	3.46	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST15(15th) -8/9/08	040820778-0010	South Face - East end at corner (scaffolding level: 15th floor)	8/9/08	3.55	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST16(15th) -8/9/08	040820778-0011	East Face - North end at corner (scaffolding level: 15th floor)	8/9/08	3.54	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST17(15th) -8/9/08	040820778-0012	North Face - West end at corner (scaffolding level: 15th floor)	8/9/08	3.6	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST1-8/10/08	040820803-0001	Southwest Area (sidewalk bridge level)	8/10/08	3.97	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST2-8/10/08	040820803-0002	Southeast Area (sidewalk bridge level)	8/10/08	3.95	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST4-8/10/08	040820803-0003	Northwest Area (street-level)	8/10/08	3.73	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST5-8/10/08	040820803-0004	Firehouse #10 (roof level)	8/10/08	3.66	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST10-8/10/08	040820803-0005	North Side Sidewalk Bridge	8/10/08	3.54	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST11-8/10/08	040820803-0006	90 Trinity Place (roof level)	8/10/08	3.59	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST12-8/10/08	040820803-0007	110 Greenwich Street (roof level)	8/10/08	3.62	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST13-8/10/08	040820803-0008	Marriott Hotel, 38th Floor (roof level)	8/10/08	3.53	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST14(15th) -8/10/08	040820803-0009	West Face - South end at corner (scaffolding level: 15th floor)	8/10/08	4	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST15(15th) -8/10/08	040820803-0010	South Face - East end at corner (scaffolding level: 15th floor)	8/10/08	4.09	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST16(15th) -8/10/08	040820803-0011	East Face - North end at corner (scaffolding level: 15th floor)	8/10/08	3.92	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST17(15th) -8/10/08	040820803-0012	North Face - West end at corner (scaffolding level: 15th floor)	8/10/08	4.02	Silica	NIOSH 7500 XRD	EMSL	8/11/08	< 1	No	No	
SILICA-ST1-8/11/08	040820942-0001	Southwest Area (sidewalk bridge level)	8/11/08	3.55	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 1	No	No	
SILICA-ST2-8/11/08	040820942-0002	Southeast Area (sidewalk bridge level)	8/11/08	3.79	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 1	No	No	
SILICA-ST4-8/11/08	040820942-0003	Northwest Area (street-level)	8/11/08	3.36	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 1	No	No	
SILICA-ST5-8/11/08	040820942-0004	Firehouse #10 (roof level)	8/11/08	3.61	Silica	NIOSH 7500 XRD	EMSL	8/12/08	2	No	No	
SILICA-ST10-8/11/08	040820942-0005	North Side Sidewalk Bridge	8/11/08	3.55	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 1	No	No	
SILICA-ST11-8/11/08	040820942-0006	90 Trinity Place (roof level)	8/11/08	3.56	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 1	No	No	
SILICA-ST12-8/11/08	040820942-0007	110 Greenwich Street (roof level)	8/11/08	3.6	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 1	No	No	
SILICA-ST13-8/11/08	040820942-0008	Marriott Hotel, 38th Floor (roof level)	8/11/08	3.6	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 1	No	No	
SILICA-ST14(15th) -8/11/08	040820942-0009	West Face - South end at corner (scaffolding level: 15th floor)	8/11/08	3.47	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 1	No	No	
SILICA-ST15(15th) -8/11/08	040820942-0010	South Face - East end at corner (scaffolding level: 15th floor)	8/11/08	3.44	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 1	No	No	
SILICA-ST16(15th) -8/11/08	040820942-0011	East Face - North end at corner (scaffolding level: 15th floor)	8/11/08	3.24	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 2	No	No	
SILICA-ST17(15th) -8/11/08	040820942-0012	North Face - West end at corner (scaffolding level: 15th floor)	8/11/08	3.34	Silica	NIOSH 7500 XRD	EMSL	8/12/08	< 1	No	No	